

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Haskell	Fraction NE 1/4 NE 1/4 NE 1/4	Section number 17	Township number T 28	Range number S R 31	E/W E/W
2. Distance and direction from nearest town or city: 6 mi E + 7 N. of Sublette				3. Owner of well: Salem Mennonite Church			
Street address of well location if in city:				R.R. or street: City, state, zip code: Copeland, Kansas 67837			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 9 in. Completion date Well depth 300 ft. 5/8/77			
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
5. Type and color of material		From		To		9. Casing: Material PVC Height: Above or below	
						Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 14 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 240 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 0258	
Overburden Sand + Gravel Blue Clay		0 165 165 295 295 300		10. Screen: Manufacturer's name J-L Type PVC Dia. 5" Slot/gauze 1/4 Length 60 Set between 240 ft. and 300 ft. Gravel pack? Yes Size range of material 1/8"			
				11. Static water level: 165 ft. below land surface Date 5/8/77 12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 80 g.p.m.			
				13. Water sample submitted: ____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____			
				14. Well head completion: <input type="checkbox"/> Pitless adapter 14 inches above grade			
				15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.			
				16. Nearest source of possible contamination: ft. 600 Direction NW Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. T & W Water Well 142 Business name License No. Address Box 816 Liberal, KS Signed C. W. [Signature] Date 6/1/77 Authorized representative			
18. Elevation:		19. Remarks:		20. Water well contractor's certification:			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		17. Well to be completed by: Dunham Drilling Copeland, KS. 67837		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. T & W Water Well 142 Business name License No. Address Box 816 Liberal, KS Signed C. W. [Signature] Date 6/1/77 Authorized representative			