


Drilled for Dunham Drilling-Copeland Kansas

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Haskell	Township name Lockport	Fraction NW 1/4 of SW 1/4	Section number 20	Town number T-28-S	Range number R-31-W
Distance and direction from nearest town or city: 7 mi north and 5 mi east of Sublette, Kansas				3 Owner of well: Martha D. Burkner Address: 1231 Porter Ave. Stockton, Calif.		
Locate with "X" in section below: 				Sketch map: 4 Well depth: 465 ft. Date of completion 6-10-75 Well diameter 26 in. 5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary 6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/> 7 Casing: Material Metal Height: above/below 12" Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 16 in. to 465 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No _____ in. to _____ ft. depth!		
2				From	To	
Type and color of material						
Overburden				0	200	
Sand and gravel				200	240	
Sand and gravel				240	257	
Clay				257	260	
Clay				260	280	
Blue clay				280	320	
Fine sand and blue clay				320	360	
Blue clay				360	400	
Sand and gravel with clay and sandstone streaks				400	420	
Coarse sand and clay streaks				420	440	
Medium sand and clay streaks				440	460	
Fine sand and clay streaks				460	480	
(use a second sheet if needed)						
16 Remarks: elevation Casing-plain is .188 wall weighing 31.66 per ft. Perf. is .219 wall weighing 36.87 per ft. Topography: <input type="checkbox"/> Hill Dunham Drilling will do grouting-test pumping and set pump <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Ace-Hi Drilling Co 190 Business name License No. Address Box 1442, Dodge City, Ks Signed Carl G. Tuttle Date 6-17-75 Authorized representative		