

ssionals

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

Warren Nichols
Haskell County
3-27-86

Location: NW $\frac{1}{4}$ 14-28-31
4 $\frac{1}{2}$ Miles south of popcorn factory south of
Pierceville, $\frac{1}{2}$ Mile east - 600' east of
existing well.

Static Water Level - 260?

Test #1

0	2	Top soil
2	33	Brown clay
33	50	Brown sandy clay & white clay
50	89	Brown sandy clay
89	101	Brown sandy clay & fine sand
101	126	Brown sandy clay
126	268	Fine to medium sand & gravel (loose)
268	272	Fine to medium sand & gravel (tight)
272	289	Fine to medium sand & gravel (loose)
289	320	Blue & brown clay
320	346	Gray clay
346	410	Gray clay - streak of fine sand (25%)
410	440	Gray & brown clay
440	452	Gray & brown clay - small streak of fine sand
452	486	Sand stone - streak of gray clay (10%) (loose)
486	528	Gray clay, brown clay & sandstone (tight)
528	540	Fine to medium sand & fine gravel - streak of clay (40%) (loose)
540	653	Fine to medium sand & gravel - streak of clay (20%) (loose)
653	665	Shale