


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Haskell	Fraction SW 1/4 SW 1/4 SW 1/4	Section number 4	Township number T 28 S	Range number R 32 E
2. Distance and direction from nearest town or city: 10 N & 1/2 E of Sublette Street address of well location if in city:			3. Owner of well: Forrest Cox R.R. or street: City, state, zip code: Sublette, KS 67877		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile		Sketch map: 		6. Bore hole dia. 26 in. Completion date 1-12-77 Well depth 570 ft.	
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
See attachment				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36 lbs./ft. Dia 16 in. to 570 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 219	
				10. Screen: Manufacturer's name Brown Type Louvered Dia. 16" Slot/gauze .125 Length 130 Set between 465 ft. and 335 ft. ft. and ft. Gravel pack Yes Size range of material 1/4 x 1/8	
				11. Static water level: 217 ft. below land surface Date 1-14-77 mo./day/yr.	
				12. Pumping level below land surfaces: 282 ft. after <input type="checkbox"/> hrs. pumping 1404 g.p.m. ft. after <input type="checkbox"/> hrs. pumping g.p.m. Estimated maximum yield g.p.m.	
				13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date	
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade	
				15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
				16. Nearest source of possible contamination: None observed ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
		(Use a second sheet if needed)			
18. Elevation: Flat Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drlg. & Supply 145 Business name License No. Address Box 639 Garden City, KS Signed E. L. B. Thomas Date 1-27-77 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

DRILLERS TEST LOG

CUSTOMERS NAME Forrest Cox DATE 12-20-76
 STREET ADDRESS _____ TEST # 1 E. Log
 CITY & STATE Sublette, KS DRILLER Martinez
 COUNTY Haskell QUARTER SW SECTION 4 TOWNSHIP 28 RANGE 32

LOCATION SW corner of the SW $\frac{1}{4}$

%	DRILLED FOOTAGE			Description of Strata	WELL LOCATION	
	From	Pay	To		Static Water Level	Proposed Well Depth
	0		3	Top soil		
	3		20	Brown clay		
	20		51	Sand fine to med.		
	51		60	Brown clay		
	60		75	Sand fine to med.		
	75		109	Brown clay		
30	109	7	247	Sand fine to med. coarse, small to large gravel, few cemented st., used water		
	247		252	Brown clay, sticky		
	252		260	Brown clay, few sand st.		
60	260	15	275	Sand fine to med. coarse, small to med. gravel. loose, used water		
	275		284	Yellow clay, sticky		
40	284	6	290	Sand fine to med. coarse, loose, used water		
	290		300	Yellow and blue clay, sticky		
40	300		335	Light blue clay, sticky		
40	335	5	340	Sand fine to med. coarse, loose, used water, clay st., few lime rock st.		
55	340	130	473	Sand fine to med. coarse, small gravel, loose, used water, few clay st. and lime rock st.		
	473		521	Brown sandy clay, few lime rock st.		
70	521	39	560	Sand fine to med. coarse, small brown gravel, loose, used water		
	560		575	Brown clay, few lime rock ledges		
	575		610	Soapstone, very few white Dakota st., drills tight		
	610		620	Lime rock, very hard		
		202				
				TOTAL DEPTH OF WELL 570 FT.		
				Set up north		
				Pit on east		
					4 Quik-Gel	
					1 lime	