

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County HASKELL	Fraction NE 1/4 NE 1/4 NE 1/4	Section number 24	Township number T 28 S	Range number R 32 EW
2. Distance and direction from nearest town or city: 4 1/2 E Sublette 7 1/4 N. Street address of well location if in city:			3. Owner of well: Paul Weidner R.R. or street: St Rt Box 62 City, state, zip code: Sublette Kansas		
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map:		6. Bore hole dia. 9 in. Completion date 11/19/80 Well depth 275 ft.	
5. Type and color of material		From		To	
		overburden		0 210	
		medium to coarse sand		210 240	
		coarse sand + clay		240 270	
		blue shale		270 275	
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 14 in. RMP PVC Weight 140 lbs./ft. Dia. 5 in. to 215 ft. depth Wall Thickness: inches or Dia. 5 in. to 215 ft. depth gage No. 6258	
				10. Screen: Manufacturer's name Peerless Type PVC Dia. 5" Slot/gauze 1/16 Length 80 Set between 215 ft. and 275 ft. Gravel pack? Yes Size range of material 1/8	
				11. Static water level: 210 ft. below land surface Date 11/19/80 mo./day/yr.	
				12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 45 g.p.m.	
				13. Water sample submitted: ____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date ____	
				14. Well head completion: <input type="checkbox"/> Pitless adapter 14 inches above grade	
				15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 13 ft.	
				16. Nearest source of possible contamination: none ft. ____ Direction ____ Type ____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
		(Use a second sheet if needed)			
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks: 17 Pump to be installed by dunham drilling - Copeland Ks		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. T. W. WATER WELLER 142 Business name Box 816 Liberal Ks 67401 License No. ____ Address Liberal Ks 67401 Signed T. W. Waterweller Date 12/1/80 Authorized representative	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5