

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Haskell	Fraction SW 1/4 SW 1/4 NE 1/4	Section number 24	Township number T 28 S R 32 EW	Range number
2. Distance and direction from nearest town or city: Approximately 7 3/4 miles NW of Copeland, Kansas. Street address of well location if in city:			3. Owner of well: Paul Weidner R.R. or street: City, state, zip code: Sublette, Kansas 67877		
4. Locate with "X" in section below: Sketch map:			6. Bore hole dia. <u>26</u> in. Completion date <u>3/13/79</u> Well depth <u>546</u> ft.		
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material			9. Casing: Material <u>Steel</u> Height: <u>Above</u> or below Threading: <input type="checkbox"/> Threaded <input checked="" type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>42.05</u> lbs./ft. Dia. <u>16</u> in. to <u>546</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth Gage No. <u>250</u>		
See Attachment			10. Screen: Manufacturer's name <u>W. A. Brown</u> Type <u>Louvered</u> Dia. <u>16"</u> <input checked="" type="checkbox"/> Slot/gauze <u>.100</u> Length <u>86'</u> Set between <u>398</u> ft. and <u>438</u> ft. <u>480 - 520</u> ft. and <u>540 - 546</u> ft. Gravel pack? <u>Yes</u> Size range of material <u>#1 Coarse</u>		
			11. Static water level: <u>229</u> ft. below land surface Date <u>3/16/79</u> mo./day/yr.		
			12. Pumping level below land surfaces: <u>350</u> ft. after <u> </u> hrs. pumping <u>1310</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>1,300</u> g.p.m.		
			13. Water sample submitted: <u> </u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>		
			14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> Inches above grade		
			15. Well grouted? <u>Yes</u> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
			16. Nearest source of possible contamination: <u>None Observed</u> ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u> </u> Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
			(Use a second sheet if needed)		
			18. Elevation: <input checked="" type="checkbox"/> Flat Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:	

T 28 S R 32 EW
 Sec 24
 SW 1/4 NW 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

