

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County Haskell	Fraction NW 1/4 NW 1/4 SE 1/4	Section number 33	Township number T 28 S R 32 E 10	
2. Distance and direction from nearest town or city: Approx 6 miles north and 1 mile east of Sublette Street address of well location if in city:			3. Owner of well: Neumann & Wheatley Farms R.R. or street: RR #1 City, state, zip code: Isabel, ks 67065		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>26</u> in. Completion date 9/14/79 Well depth 549 ft.	
		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material <u>steel</u> Height: <u>above</u> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>42.05</u> lbs./ft. Dia. <u>16</u> in. to <u>549</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>250</u>	
5. Type and color of material			From	To	10. Screen: Manufacturer's name <u>W.A. Brown</u>
See attached log					Type <u>louvered</u> Dia. <u>16"</u> Slot/gauze <u>0.80"</u> Length <u>150"</u> Set between <u>355-435</u> ft. and <u>460-500</u> ft. <u>519-549</u> ft. and <u> </u> ft. Gravel pack? <u>yes</u> Size range of material <u>21 coarse</u>
					11. Static water level: <u>232</u> ft. below land surface Date <u>8/15/79</u> mo./day/yr.
					12. Pumping level below land surfaces: <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>1700</u> g.p.m.
					13. Water sample submitted: <u> </u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>
					14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> Inches above grade
					15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.
					16. Nearest source of possible contamination: <u>None</u> ft. <u> </u> Direction <u> </u> Type <u>Observed</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u> </u> Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drilling & Supply 145 Business name License No. Address <u>Overden City, ks 67846</u> Signed <u>Bruce J. Richardson</u> Date <u>9/14/79</u> Authorized representative
18. Elevation: X Flat	19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

T 28 R 32 E 10 Sec 33 NW 1/4 SE 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

