

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Haskell		Fraction NE 1/4 NE 1/4 NE 1/4		Section number 33		Township number T 28 S R 32 E 10		Range number	
2. Distance and direction from nearest town or city: Approx 6 1/2 miles north and 1 1/2 miles east of Sublette Street address of well location if in city:				3. Owner of well: Neumann and Wheatley Farms R.R. or street: R.R. #1 City, state, zip code: Isabel, ks 67065					
4. Locate with "X" in section below: Sketch map:				6. Bore hole dia. 2 1/2 in. Completion date 8/11/79 Well depth 433 ft.					
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary					
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other					
5. Type and color of material				From		To			
See attached log				9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 42.65 lbs./ft. Dia. 1 1/2 in. to 563 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250					
				10. Screen: Manufacturer's name W. A. Brown Type Leveled Dia. 1 1/2 " Slot/gauze 100 " Length 160 " Set between 307-324 ft. and 346-426 ft. 467-477 ft. and 500-530 ft. 540-560 Gravel pack? Yes Size range of material #1 Course					
				11. Static water level: <input type="checkbox"/> mo./day/yr. 232 ft. below land surface Date 8/11/79					
				12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 1800 g.p.m.					
				13. Water sample submitted: ____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____					
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade					
				15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.					
				16. Nearest source of possible contamination: None ft. ____ Direction ____ Type observed Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No					
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
				(Use a second sheet if needed)					
18. Elevation: <input checked="" type="checkbox"/> Flat Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drilling & Supply 145 Business name License No. ____ Address Garden City, ks. 67846 Signed Bruce J Reichmuth Date 9/14/79 Authorized representative					

T
2
8
3
2
E
3
3
1/4 NE
1/4 NE
1/4 NE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

DRILLING TEST LOG

CUSTOMERS NAME Neumann & Wheatley DATE 7-25-79
 STREET ADDRESS % John Neumann TEST # 1 E. LOG Yes
 CITY & STATE Isabel, KS 67065 DRILLER Livingston
 COUNTY Haskell QUARTER NE SECTION 33 TOWNSHIP 28 RANGE 32
 LOCATION 125 ft. west of the NE corner of the 1/4 Well location

%	FOOTAGE		DESCRIPTION OF STRATA	Static Water Level
	From	Pay To		Proposed Well Depth
	0	1	Top soil	
	1	50	Clay & gyp. and fine sand	
	50	230	Sand fine to med. coarse small to large gravel, few cemented lodges	
	230	246	Yellow clay and sand st.	
70	246	61 307	Sand fine to med. coarse small to med. gravel	
	307	335	Yellow clay and sand st.	
	335	351	Blue clay	
50	351	08 359	Sand fine to med. coarse small gravel	
	359	386	Brown sandy clay & lime rock	
70	386	10 396	Sand fine to med. coarse small to med. gravel	
	396	405	Brown sandy clay	
50	405	07 412	Sand fine to med. coarse few small gravel	
	412	426	Brown sandy clay & lime rock	
60	426	20 446	Sand fine to med. coarse small gravel	
	446	466	Brown sandy clay lime rock	
15	466	11 477	Sand fine small & clay	
	477	497	Brown clay & lime rock	
40	497	23 520	Sand fine to med. and sandy clay, used water	
	520	530	Brown clay	
70	530	10 540	Sand fine to med. coarse small to med. brown gravel.	
	540	550	Brown clay, lime rock	
fair	550	10 560	Brown rock, snadstone and soapstone	
	560	566	Yellow soapstone	
	566	580	Weathered shale	
		159		
			Total depth	563'
			Set up west	
			dig pit on the north	

GARDEN CITY, KS HENKLE DRILLING & SUPPLY CO., INC. SUBLETTE, KS
 Phone 276-3278 IRRIGATION HEADQUARTERS Phone 675-4311
 TEST HOLES * * * * * IRRIGATION & INDUSTRIAL WELLS * * * * * STOCK WELLS