

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY—PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County: Haskell	Fraction: NW 1/4 NW 1/4 NW 1/4	Section number: 1	Township number: T 28 S R 33	Range number: 33
2. Distance and direction from nearest town or city: *See Below			3. Owner of well: Mary Jane Trembley		
Street address of well location if in city:			R.R. or street: C/O John Hays		
			City, state, zip code: Sublette, Kansas 67877		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 2 1/2 in. Completion date 5/20/77	
		<p>* 1 1/2 mi W on Hi-way #56, 12 mi N on Hi-way #83, 1 mi W on section line paved road from Sublette, Kansas.</p>		Well depth 353 ft.	
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
<p>See Attachments</p>				9. Casing: Material Steel Height: <input type="checkbox"/> Above <input checked="" type="checkbox"/> Below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 31 lbs./ft. Dia. 3 1/2 in. to 555 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 218	
		10. Screen: Manufacturer's name Johnson			
		Type Continuous Dia. 16"			
		Slot/gauze 125 Length 40'			
		Set between 210 ft. and 250 ft.			
		Gravel pack? Yes Size range of material 3" down			
		11. Static water level: 193 ft. below land surface Date 5/24/77			
		12. Pumping level below land surfaces: 22 1/2 ft. after <input type="checkbox"/> hrs. pumping 1451 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1,500 g.p.m.			
		13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>			
		14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade			
15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.					
16. Nearest source of possible contamination: None ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Observed Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No					
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
(Use a second sheet if needed)					
18. Elevation: <input checked="" type="checkbox"/> Flat Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drillings & Sply 145 Business name License No. <input type="checkbox"/> Address Box 639, Garden City, K Signed E. L. Bothwell Date 5/25/77 Authorized representative		

T 28 S R 33 E 1
 Sec 1
 1/4 NW 1/4 NW 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

DRILLERS TEST LOG

CUSTOMERS NAME Mary Jane Trembley DATE 3-22-77
 STREET ADDRESS c/o John Hays TEST # 2 E. LOG 560'
 CITY & STATE Sublette, KS DRILLER Rector
 COUNTY Haskell QUARTER NW SECTION 1 TOWNSHIP 28 RANGE 33
 LOCATION 700' W of Test #1

WELL LOCATION

%	FOOTAGE		DESCRIPTION OF STRATA	Static Water Level
	From	Pay To		Proposed Well Depth
	0	3	Top soil	
	3	45	Brown sandy clay and fine sand	
	45	60	Brown clay and caliche	
	60	100	Brown sandy clay and sand	
55	100	57	232	Sand fine med. coarse, small and some large gravel, ragged in places, very small clay sts.
	232		238	Brown clay, caliche and sand
55	238	10	248	Sand fine med. coarse and small gravel
	248		260	Brown clay and lime rock sts.
	260		320	Blue clay
	320		340	Blue clay, small ledges and small sand sts.
65	340	60	400	Sand fine med. coarse, small gravel, small clay and lime rock sts.
	400		410	Brown clay and lime rock
60	410	25	435	Sand fine med. coarse, small gravel, brown clay and lime rock sts.
	435		517	Brown clay, lime rock and sand
75	517	35	552	Brown sand and gravel, fine med. coarse, and brown and tan rock, used lots of water
	552		560	Brown and yellow clay
		187		
				TOTAL DEPTH OF WELL 555 FT.
				Set up facing west
				Dig pit on north

GARDEN CITY, KS
 Phone 276-3278

HENKLE DRILLING & SUPPLY CO., INC.
 IRRIGATION HEADQUARTERS

SUBLETTE, KS
 Phone 675-4311

TEST HOLES * * * * * IRRIGATION & INDUSTRIAL WELLS * * * * * STOCK WELLS