


USE PENCIL OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Haskell	Fraction N$\frac{1}{2}$ 1 NE $\frac{1}{4}$ SE $\frac{1}{4}$	Section number 2	Township number T 28 S	Range number R 33 E
2. Distance and direction from nearest town or city: 2$\frac{1}{2}$ W. & 10$\frac{1}{2}$ N. of Sublette Street address of well location if in city:				3. Owner of well: Forrest Cox R.R. or street: City, state, zip code: Sublette, KS 67877		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 26 in. Completion date 8-25-76 Well depth 599 ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		See attachment		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36 lbs./ft. Dia. 16 in. to 599 ft. depth Wall Thickness: inches or Dig. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .219		
				10. Screens: Manufacturer's name Brown Type Louvered Dia. 16" Slot/gauze 1/8 Length 116 Set between 599 ft. and 563 ft. 483 ft. and 403 ft. Gravel pack? Yes Size range of material 1/8		
				11. Static water level: <input type="checkbox"/> mo./day/yr. 309 ft. below land surface Date 8-25-76		
				12. Pumping level below land surfaces: 115 ft. after <input type="checkbox"/> hrs. pumping 1357 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
				15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: Observed ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				(Use a second sheet if needed)		
18. Elevation: Flat Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drig. & Supply 145 Business name <input type="checkbox"/> License No. <input type="checkbox"/> Address Box 639 Garden City, KS Signed E. L. Bothwell Date 9-13-76 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

DRILLERS TEST LOG

CUSTOMERS NAME Forrest Cox DATE 7-13-76
STREET ADDRESS _____ TEST # 6
CITY & STATE Sublette, KS DRILLER Martinez
COUNTY Haskell QUARTER SE SECTION 2 TOWNSHIP 28 RANGE 33

LOCATION 200' S of Test #5

				WELL LOCATION	
%	DRILLED FOOTAGE		Description of Strata	Static Water Level	Proposed Well Depth
	From	Pay To			
	0	4	Top soil		
	4	21	Brown clay		
	21	61	Sand fine to med.		
	61	76	Brown sandy clay		
	76	82	Sand fine to med.		
	82	121	Brown sandy clay		
	121	215	Sand fine to med. coarse, small to large gravel, few cemented ledges		
	215	265	Brown sandy clay, lime rock st.		
	265	346	Blue clay, sticky		
70	346	97 443	Sand fine to med. coarse, small to large gravel, loose, used water, few clay st.		
60	443	18 461	Sand fine to med. coarse, small to med. gravel, loose, used water, few clay st.		
	461	561	Brown sandy clay, lime rock st., few sand st.		
75	561	40 601	Sand fine to med. coarse, small brown gravel, few brown rock st., loose in places, used water		
	601	615	Brown sandy clay, few yellow and brown rock ledges		
	615	620	Weathered shale		
		155			
			TOTAL DEPTH OF WELL 620 529 FT.		
			Set up east		
			Dig pit on south		

RDEN CITY, KANSAS HENKLE DRILLING & SUPPLY CO., INC. SUBLETTE, KANSAS
ONE 276-3278 IRRIGATION HEADQUARTERS PHONE 675-4311
BT HOLES*****STOCK WELLS*****IRRIGATION AND INDUSTRIAL WELLS*****