


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Haskell	Fraction NW 1/4 SE 1/4 SW 1/4	Section number 10	Township number T 28 S R 33 E	Range number 33
2. Distance and direction from nearest town or city: 9 1/4 miles NW of Sublette, Kansas. Street address of well location if in city:			3. Owner of well: Kenneth Cox R.R. or street: City, state, zip code: Sublette, Kansas 67877		
4. Locate with "X" in section below: <div style="text-align: center;">  </div>			Sketch map:		
5. Type and color of material			6. Bore hole dia. <u>26</u> in. Completion date <u>5/30/78</u> Well depth <u>605</u> ft.		
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material <u>Steel</u> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>42.05</u> lbs./ft. Dia. <u>16</u> in. to <u>605</u> ft. depth Wall Thickness: inches or Dia. <u>16</u> in. to <u>605</u> ft. depth gage No. <u>250</u>		
			10. Screen: Manufacturer's name <u>Johnson Screen</u> Type <u>Continuous</u> Dia. <u>16"</u> <u>Slot</u> gauze <u>100</u> Length <u>60'</u> Set between <u>330</u> ft. and <u>350</u> ft. <u>370'-390'</u> ft. and <u>410'-430'</u> ft. Gravel pack? <u>Yes</u> Size range of material <u>#1 Coarse</u>		
(Use a second sheet if needed)			11. Static water level: <u>288</u> ft. below land surface Date <u>6/2/78</u> mo./day/yr.		
			12. Pumping level below land surfaces: <u>350</u> ft. after <u> </u> hrs. pumping <u>1451</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>1,500</u> g.p.m.		
			13. Water sample submitted: <u> </u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>		
			14. Well head completion: <u> </u> Pitless adapter <u>12</u> Inches above grade		
			15. Well grouted? <u>Yes</u> With: <u> </u> Neat cement <input checked="" type="checkbox"/> Bentonite <u> </u> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
(Use a second sheet if needed)			16. Nearest source of possible contamination: <u>None</u> ft. <u> </u> Direction <u> </u> Type <u>Observed</u> Well disinfected upon completion? <u> </u> Yes <input checked="" type="checkbox"/> No		
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u> </u> Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m. Type: <u> </u> Submersible <u> </u> Turbine <u> </u> Jet <u> </u> Reciprocating <u> </u> Centrifugal <u> </u> Other		
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Henkle Drilling & Sply</u> <u>145</u> Business name License No. Address <u>Box 639, Garden City, Ks.</u> Signed <u>Bruce Richman</u> Date <u>6/7/78</u> Authorized representative		
			18. Elevation:		
			19. Remarks:		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

DRILLERS TEST LOG

CUSTOMERS NAME Kenneth Cox DATE 12/22/77
STREET ADDRESS _____ TEST # 5 E. LOG Yes
CITY & STATE Sublette, Kansas DRILLER Rector
COUNTY Haskell QUARTER SW SECTION 10 TOWNSHIP 28 RANGE 33
LOCATION From the SE corner of the 1/4, it is 1,510' N and 1,390' W.

[illegible]

GARDEN CITY, KS
Phone 276-3278

HENKLE DRILLING & SUPPLY CO., INC.
IRRIGATION HEADQUARTERS

SUBLETTE, KS
Phone 675-4311

TEST HOLES * * * * * IRRIGATION & INDUSTRIAL WELLS * * * * * STOCK WELLS