


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>Haskell County</b>	Fraction <b>1/4 1/4 NW 1/4</b>	Section number <b>11</b>	Township number <b>T 28 S.</b>	Range number <b>S R 33 X E/W</b>
2. Distance and direction from nearest town or city: <b>23 miles South, 1 1/2 West of Garden City, Kansas</b> Street address of well location if in city:			3. Owner of well: <b>Wayne Griffen</b> R.R. or street: City, state, zip code: <b>Sublette, Kansas 67877</b>			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <b>26</b> in. Completion date <b>6-30-78</b> Well depth <b>481</b> ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material <b>Steel</b> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>1 ft.</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>36.87</b> lbs./ft. Dia. <b>16</b> in. to <b>481</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <b>.219</b>		
				10. Screen: Manufacturer's name <b>Johnson</b> Type <b>Johnson Galv. 100 - 16"</b> Slot/gauze <b>0-300 Plain</b> length <b>300-360</b> Perf. Set between <b>360-400</b> Screen <b>400-457</b> Perf. <b>457-477</b> Screen and <b>477-481</b> Perf. Gravel pack? <b>yes</b> Size range of material <b>2 to 5/8</b>		
				11. Static water level: <input type="checkbox"/> mo./day/yr. <b>303 1/2</b> ft. below land surface Date <b>5-15-78</b>		
				12. Pumping level below land surfaces: <b>338</b> ft. after <b>2</b> hrs. pumping <b>825</b> g.p.m. <b>357</b> ft. after <b>4</b> hrs. pumping <b>1250</b> g.p.m. Estimated maximum yield <b>1250</b> g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
				14. Well head completion: <input type="checkbox"/> Pitless adapter <b>1 ft.</b> inches above grade		
				15. Well grouted? <b>yes</b> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.		
				16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <b>N/A</b> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <b>Could 4 stg. 14" JHC</b> Model number <b>Customere Pump</b> Volts <input type="checkbox"/> Length of drop pipe <b>400</b> ft. capacity <b>800</b> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		(Use a second sheet if needed)				
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		<b>We pulled 350' of old pump from another well and added 50'.</b>				
		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Minter-Wilson Drlg. Co. 208</b> Business name License No. <input type="checkbox"/> Address <b>Box A, Garden City, Kansas</b> Signed <b>James Minter</b> Date <b>6-20-78</b> Authorized representative				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

*The*  
*Professionals*

# MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

**WAYNE GRIFFEN**  
**HASKELL COUNTY**  
**4-11-78**

**Location:** NW 11-28-33 North west corner of  $\frac{1}{4}$   
**Static Water Level-** 240'

**Test #1**

0	1	Top soil
1	88	Brown clay
88	112	Fine to med. sand and gravel (Loose)
112	125	Fine to med. sand and gravel 15% clay (Loose)
125	239	Fine to med. sand and gravel (Loose)
239	275	Brown clay
275	298	Blue clay
298	305	Brown sandy clay 35% gravel (Loose)
305	320	Fine to med. sand and gravel 10% clay (Loose) (small hard streaks)
320	404	Fine to med. sand and gravel (Loose) (Streaks of coarse gravel )
404	416	Brown and blue clay (Hard)
416	422	Fine to med. sand and gravel (Loose)
422	459	Brown sandy clay
459	481	Fine to med. sand and gravel (Loose)
481	545	Brown clay (Tight)

**T.D. 481'**

300 Plain  
60 Perf  
40 Screen  
57 Perf  
20 Screen  
4 Perf