


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Haskell	Fraction NW 1/4 SW 1/4 SE 1/4	Section number 11	Township number T 28 S R 33 E	Range number 33 E
2. Distance and direction from nearest town or city: 9 1/4 N. & 3 W. of Sublette Street address of well location if in city:				3. Owner of well: Forrest Cox R.R. or street: Sublette, KS 67877 City, state, zip code:		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 26 in. Completion date 10-26-76 Well depth 443 ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From		To		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
See attachment						9. Casing: Material Steel Height Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36 lbs./ft. Dia. 16 in. to 443 ft. depth Wall Thickness: inches or Dia. 16 in. to 443 ft. depth gage No. 219
						10. Screen: Manufacturer's name Johnson Type Continuous Dia. 16" Slot/gauze .125 Length 60' Set between 415-395 ft. and 375-360 ft. 350-325 ft. and 325 ft. Gravel pack? Yes Size range of material 1/4 x 1/8
						11. Static water level: 284 ft. below land surface Date 10-28-76
						12. Pumping level below land surfaces: 345 ft. after 1 hrs. pumping 1435 g.p.m. 345 ft. after 1 hrs. pumping 1435 g.p.m. Estimated maximum yield 1435 g.p.m.
						13. Water sample submitted: 10-28-76 Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date 10-28-76
						14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade
						15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
						16. Nearest source of possible contamination: None observed ft. 0 Direction None Type None Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Henkle Drlg. & Supply Model number Box 639, Garden City, KS HP 145 Volts 115 Length of drop pipe 11-9 ft. capacity 11-9 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
18. Elevation: Flat Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drlg. & Supply Business name Box 639, Garden City, KS License No. 11-9 Address Box 639, Garden City, KS Signed P.L. Bothwell Date 11-9-76 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

DRILLERS TEST LOG

CUSTOMERS NAME Forrest Cox DATE 10-20-76
STREET ADDRESS _____ TEST # 1 E. Log 460'
CITY & STATE Sublette, KS DRILLER Rector
COUNTY Haskell QUARTER SE SECTION 11 TOWNSHIP 28 RANGE 33

LOCATION 100' S. of Current Well

					WELL LOCATION	
%	DRILLED		FOOTAGE	Description of Strata	Static Water Level	
	From	Pay To			Proposed Well Depth	
	0		3	Top soil		
	3		78	Brown clay and caliche		
	78		237	Sand and gravel, ragged in places and very small clay st.		
	237		262	Brown clay, lime rock and small sand sts.		
	262		323	Blue clay		
75	323	77	400	Sand fine med. coarse and small gravel, loose, used lots of water		
70	400	40	440	Sand fine med. coarse, small gravel, drilled firm, used lots of water, small lime rock and clay sts.		
	440		460	Brown clay and lime rock		
	460		480	Brown clay, sand sts. and lime rock		
	480		540	Brown clay and lime (clay sticky)		
	540		584	Brown clay and sts. of yellow clay		
	584		600	Blue shale and sts. of soapstone		
		117				
				TOTAL DEPTH OF WELL 443 FT.		
				Set up west; pit on north		

GARDEN CITY, KANSAS
PHONE 276-3278

HENKLE DRILLING & SUPPLY CO., INC.
IRRIGATION HEADQUARTERS

SUBLETTE, KANSAS
PHONE 675-4311

TEST HOLES*****STOCK WELLS*****IRRIGATION AND INDUSTRIAL WELLS*****