


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Haskell	Fraction NE 1/4 NE 1/4 NE 1/4	Section number 12	Township number T 28 S	Range number R 33 E/W
2. Distance and direction from nearest town or city: Approx. 1 1/2 miles West and 11 miles North of Sublette, Ks. Street address of well location if in city:			Owner of well: Forrest Cox R.R. or street: City, state, zip code Sublette, Ks. 67877		
4. Locate with "X" in section below: 		Sketch map:		6. Bore hole dia. 1 1/2 in. Completion date 7/24/79 Well depth 603 ft.	
5. Type and color of material SEE ATTACHED LOG		From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12" in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 18.26 lbs./ft. Dia 8 5/8 in. to 603 ft. depth Wall Thickness .203 inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gauge No. .203	
				10. Screen: Manufacturer's name Johnson Type Continuous Dia. 8 5/8 Slot/gauze .080 Length 40 Set between 420-440 ft. and 460-470 ft. 590-600 ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material #1 Fine	
				11. Static water level: <input type="checkbox"/> mo./day/yr. 250 ft. below land surface Date 7/24/79	
				12. Pumping level below land surfaces: <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 50 g.p.m.	
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>	
				14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 Inches above grade	
				15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
				16. Nearest source of possible contamination: ft. 200 Direction NE Type Ceptic Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
		(Use a second sheet if needed)			
18. Elevation: X Flat Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:				
		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drilling & Supply 145 Business name Box 639 Garden City, Ks. License No. 145 Address Box 639 Garden City, Ks. Signed Bruce Richmuth Date 8/2/79 Authorized representative			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

DRILLERS TEST LOG

CUSTOMERS NAME Forrest Cox DATE 7-6-79
STREET ADDRESS _____ TEST # 1 House wall
CITY & STATE Sublette, Wyo. 82401 DRILLER Livingston
COUNTY Haskell QUARTER NE SECTION 12 TOWNSHIP 28 RANGE 32
LOCATION 200' South West of House Wall Location House Wall
approx. 400' South & 400' West of North East corner of the NE_{1/4}

%	FOOTAGE		DESCRIPTION OF STRATA	Static Water Level 215'
	From	Pay To		Proposed Well Depth
	0	2	Top Soil	
	2	90	Brown Sandy Clay, fine sand st. & Caliche	
	90	250	Sand fine to Med. small to Large, few clay st. & cemented Ledges	
	250	257	Brown Clay	
60	257	265	Sand fine to Med. coarse small	
	265	286	Brown clay, lime rock ledges & few sand st.	
	286	370	Blue Clay Sand from 305' - 310'	
	370	390	Sand fine to med. coarse & clay	
70	390	446	Sand fine to Med. coarse. Small to Med. gravel	
	446	455	Brown sandy clay, lime rock ledges	
85	455	493	Sand fine to med. coarse, small gravel	
	493	590	Brown sandy clay & few sands st.	
70	590	600	Sand fine to med. coarse, small brown gravel.	
	600	610	Soapstone & lime stone.	
			Total Depth	or 603'
			Set up SOUTH	
			PITS ON THE WEST	
			GAS LINE APPROX. 30' WEST OF TEST HOLE	
			STAKE IN FENCE LINE FOR GAS LINE.	

GARDEN CITY, KS
Phone 276-3278

HENKLE DRILLING & SUPPLY CO., INC.
IRRIGATION HEADQUARTERS

SUBLETTE, KS
Phone 675-4311

TEST HOLES * * * * * IRRIGATION & INDUSTRIAL WELLS * * * * STOCK WELLS