


USE TYPEWRITER OR BALL
POINT PEN. PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Haskell	Fraction NE 1/4 NE 1/4 SW 1/4	Section number 16	Township number T 28 S R 33 E/W	Range number 33
2. Distance and direction from nearest town or city: Approximately 8 3/4 miles NW of Sublette, Kansas. Street address of well location if in city:				3. Owner of well: Mrs. Lloyd Randle R.R. or street: 306 West 2nd street City, state, zip code: Pratt, Kansas 67124		
4. Locate with "X" in section below: 				Sketch map:		
5. Type and color of material				From	To	6. Bore hole dia. 26 in. Completion date 9/19/78 Well depth 538 ft.
See Attachment						7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
						8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
						9. Casing: Material Steel Height: Above or below surface 12 in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.91 lbs./ft. Dia. 16 in. to 538 ft. depth Wall Thickness: inches or Dia. 16 in. to 538 ft. depth gage No. .219
						10. Screen: Manufacturer's name Johnson Screen Type Continuous Dia. 16 in. Slot/gauze .100 Length 60 ft. Set between 350 ft. and 390 ft. 420 ft. and 515 ft. and 525 ft. Gravel pack Yes Size range of material 1/2" down
						11. Static water level: 325 ft. below land surface Date 9/21/78 mo./day/yr.
						12. Pumping level below land surfaces: 384 ft. after 1326 g.p.m. ft. after 1330 g.p.m. Estimated maximum yield 1,330 g.p.m.
						13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date
						14. Well head completion: Pitless adapter 12 inches above grade
						15. Well grouted? Yes With: Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete <input type="checkbox"/> Depth: From 0 ft. to 10 ft.
						16. Nearest source of possible contamination: None observed ft. Direction Type Observed Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other <input type="checkbox"/>
(Use a second sheet if needed)						
18. Elevation: x Flat Topography: Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley <input type="checkbox"/>		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drilling & Sply 145 Business name License No. Address Box 639, Garden City, KS Signed E. L. Bothwell Date 9/22/78 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

DRILLERS TEST LOG

CUSTOMERS NAME Mrs. Lloyd Randle DATE 12-8-76
 STREET ADDRESS _____ TEST # 2 E. Log
 CITY & STATE Pratt, Kansas DRILLER Martinez
 COUNTY Haskell QUARTER SW SECTION 16 TOWNSHIP 28 RANGE 31

LOCATION N.E. corner of the S.W. 1/4.

WELL LOCATION

	DRILLED		FOOTAGE	Description of Strata	Static Water Level
	From	Pay To			Proposed Well Depth
	0		3	Top soil	
	3		68	Brown clay	
	68		80	Sand fine to med. coarse, small to large gravel	
	80		85	Brown clay	
	85		120	Sand fine to med. coarse, small gravel	
	120		223	Sand fine to med. coarse, small to large gravel	
	223		240	Brown clay, few sand st.	
	240		260	Blue clay, sticky	
	260		290	Blue and brown clay, sticky	
50	290	11	301	Sand fine to med. coarse, small and few med. gravel, loose, used water	
	301		335	Blue sand, fine to med., blue clay st.	
40	335	5	340	Sand fine to med. coarse, loose, used water	
70	340	51	391	Sand fine to med. coarse, small to med. gravel, loose, used water	
	391		400	Brown clay	
60	400	10	410	Sand fine to med. coarse, small gravel, loose, used water	
	410		418	Brown sandy clay	
60	418	36	452	Sand fine to med. coarse, small gravel, loose, used water	
	452		480	Brown sandy clay, few lime rock st.	
40	480	8	489	Fine sand, loose, used water	
	489		520	Brown sandy clay, few lime rock st.	
70	520	15	535	Sand fine to med. coarse, small brown gravel, loose, used water	
	535		550	Brown sandy clay	
	550		590	Yellow clay, soapstone	
	590		600	Weathered shale	
		136			
				TOTAL DEPTH OF WELL 538 FT.	
				Set up west	
				Pit on north	

GARDEN CITY, KANSAS HENKLE DRILLING & SUPPLY CO., INC. SUBLETTE, KANSAS
 PHONE 276-3278 IRRIGATION HEADQUARTERS PHONE 675-4311

TEST HOLES*****STOCK WELLS*****IRRIGATION AND INDUSTRIAL WELLS*****