

1 LOCATION OF WATER WELL		Fraction	Section Number	Township Number	Range Number		
County: Haskell		$\frac{1}{4}$ $\frac{1}{4}$ SW $\frac{1}{4}$	17	T 28 S	R 33 EW		
Distance and direction from nearest town or city? Sublette - 1 1/2 West Street address of well if located within city? 9 North - 4 5/8 West - 1/2 North							
2 WATER WELL OWNER: Glenn Converse (Mrs.)							
RR#, St. Address, Box #: 1024 W. 4							
City, State, ZIP Code: Larned, KS 67550							
Board of Agriculture, Division of Water Resources Application Number:							
3 DEPTH OF COMPLETED WELL: 450 ft. Bore Hole Diameter: 26 in. to 450 ft. and in. to ft.							
Well Water to be used as:							
1 Domestic 3 Feedlot 5 Public water supply 8 Air conditioning 11 Injection well 2 Irrigation 4 Industrial 6 Oil field water supply 9 Dewatering 12 Other (Specify below) 7 Lawn and garden only 10 Observation well							
Well's static water level: 335 Approx. below land surface measured on January month 16 day 1980 year							
Pump Test Data: Well water was ft. after hours pumping gpm							
Est. Yield gpm: Well water was ft. after hours pumping gpm							
4 TYPE OF BLANK CASING USED:							
1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile Casing Joints: Glued Clamped 2 PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below) Welded X 7 Fiberglass Threaded							
Blank casing dia: 16 in. to 450 ft. Dia in. to ft. Dia in. to ft.							
Casing height above land surface: 12 in., weight 36.4 lbs./ft. Wall thickness or gauge No. .219							
TYPE OF SCREEN OR PERFORATION MATERIAL:							
1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 10 Asbestos-cement 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 11 Other (specify) 12 None used (open hole)							
Screen or Perforation Openings Are:							
1 Continuous slot 3 Mill slot 5 Gauzed wrapped 8 Saw cut 11 None (open hole) 2 Louvered shutter 4 Key punched 6 Wire wrapped 9 Drilled holes 7 Torch cut 10 Other (specify)							
Screen-Perforation Dia: 16 in. to 450 ft. Dia in. to ft. Dia in. to ft.							
Screen-Perforated Intervals: xxx Screen 350-375 ft. xxx Perf 375-385 ft. xxx Screen 385-415 ft. xxx Perf 415-425 ft.							
xxxx Screen 425-445 ft. xxx Perf 445-450 ft. From ft. to ft.							
Gravel Pack Intervals: From 10 ft. to 450 ft. From ft. to ft.							
From ft. to ft. From ft. to ft.							
5 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other							
Grouted Intervals: From 0 ft. to 10 ft. From ft. to ft. From ft. to ft.							
What is the nearest source of possible contamination:							
1 Septic tank 4 Cess pool 7 Sewage lagoon 10 Fuel storage 14 Abandoned water well 2 Sewer lines 5 Seepage pit 8 Feed yard 11 Fertilizer storage 15 Oil well/Gas well 3 Lateral lines 6 Pit privy 9 Livestock pens 12 Insecticide storage 16 Other (specify below) 13 Watertight sewer lines Center of 1/2 Section N/A							
Direction from well: How many feet? Water Well Disinfected? Yes X No							
Was a chemical/bacteriological sample submitted to Department? Yes X No If yes, date sample was submitted month day year: Pump Installed? Yes X No							
If Yes: Pump Manufacturer's name Used Customers Pump Model No. HP Volts							
Depth of Pump Intake 460 ft. Pumps Capacity rated at gal./min.							
Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other							
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on July month 28 day 1980 year							
And this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 208							
This Water Well Record was completed on October month 23 day 1980 year under the business name of Minter Wilson Drilling Co., Inc. by (signature) <i>Minter Wilson</i>							
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG
				Test log attached			
ELEVATION:							
Depth(s) Groundwater Encountered		1. ft.	2. ft.	3. ft.	4. ft.	(Use a second sheet if needed)	

INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.

OFFICE USE ONLY

T

R

SEC.

1/4

C of SW 1/4

TOPEKA CITY, KANSAS

January 17, 1930

Scott Main
Haskell County

Location: SW 17-28-33 - Test Hole next to rail water pit

Static Water Level 335

Test 3

0	1	Top Soil
1	55	Brown Clay
55	93	Red. to Coarse Gravel (Loose)
93	155	Fine to Red. Sand & Gravel Streaks of Coarse Gravel (Loose)
155	179	Brown Clay 30% Gravel
179	214	Fine to Red. Sand & Gravel 10% Clay (Loose)
214	220	Brown Clay
220	228	Fine to Red. Sand & Gravel 10% Clay (Loose)
228	245	Fine to Red. Sand & Fine Gravel 20% Clay (Loose)
245	269	Fine to Red. Sand & Gravel 15% Clay (Loose)
269	290	Brown Clay
290	303	Blue Clay
303	374	Fine to Red. Sand & Gravel (Loose)
374	385	Brown Clay
385	418	Fine to Red. Sand & Gravel 10% Clay (Loose)
418	425	Brown Sandy Clay
425	448	Fine to Red. Sand & Gravel (Loose)
448	457	Brown Clay (Tight)
457	485	Brown & Gray Clay with White Rock (Hard)
485	504	Gray & Yellow Clay with Brown & White Rock (Hard)
504	510	Shale (Hard)