


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Haskell	Fraction SW 1/4 SE 1/4 SE 1/4	Section number 19	Township number T 28 S R 33 E	Range number 33
2. Distance and direction from nearest town or city: Approximately 8 miles N/W of Sublette, Kansas Street address of well location if in city: Loc,		3. Owner of well: Forrest Cox R.R. or street: Sublette, Kansas 67877 City, state, zip code:			
4. Locate with "X" in section below: 		Sketch map:		6. Bore hole dia. 26 in. Completion date 12/13/77 Well depth 532 ft.	
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
See Attachment				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 42.05 lbs./ft. Dia 16 in. to 532 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .250	
				10. Screen: Manufacturer's name Johnson Screen Type Continuous Dia. 16" Slot/gauze .125 Length 60' Set between 341 ft. and 381 ft. 509 ft. and 529 ft. Gravel pack? Yes Size range of material #1 Coarse	
				11. Static water level: <input type="checkbox"/> mo./day/yr. 300 ft. below land surface Date 12/15/77	
				12. Pumping level below land surfaces: 1,435 336 ft. after <input type="checkbox"/> hrs. pumping 14/77 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1,500 g.p.m.	
				13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>	
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade	
				15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
				16. Nearest source of possible contamination: None ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type Observed Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation: x Flat		19. Remarks:			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drilling & Sply 145 Business name License No. <input type="checkbox"/> Address Box 639, Garden City, KS Signed Bruce J. Richmond Date 12/16/77 Authorized representative			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

DRILLERS TEST LOG

CUSTOMERS NAME Forrest Cox DATE 11/14/77
 STREET ADDRESS _____ TEST # 9 E. LOG Yes
 CITY & STATE Sublette, Kansas DRILLER Martinez
 COUNTY Haskell QUARTER SE SECTION 19 TOWNSHIP 25 RANGE 33
 LOCATION 232' N of Test Hole #4.

				WELL LOCATION	
%	FOOTAGE			Static Water Level _____	
	From	Pay	To	DESCRIPTION OF STRATA	Proposed Well Depth _____
	0		2	Top Soil	
	2		60	Brown clay	
	60		160	Sand fine to med coarse, small to large gravel.	
	160		165	Brown clay - sticky.	
	165		172	Sand fine to med coarse.	
	172		190	Brown clay - sticky	
	190		240	Sand fine to med coarse.	
	240		290	Blue clay - sticky.	
50	290	10	300	Sand fine to med coarse. Loose - used water.	
45	300	40	340	Sand fine to med with a few coarse. Loose - used some water.	
55	340	20	360	Sand fine to med coarse, a few small gravel. Loose - used water.	
60	360	21	381	Sand fine to med coarse, small gravel. Loose - used water. Had a few clay sts.	
	381		425	Brown clay	
55	425	26	451	Sand fine to med coarse, a few small gravel. Loose, used water.	
	451		509	Brown clay	
70	509	20	529	Sand fine to med coarse, small brown gravel. Loose, used water. Had a few brown rock sts.	
	529		541	yellow clay	
	541		600	weather shale	
		137			
				TOTAL DEPTH 532'	
				Set up facing North	
				Pit on the East	