


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Haskell	Fraction SW $\frac{1}{4}$ NE $\frac{1}{4}$ SW $\frac{1}{4}$	Section number 25	Township number T 28 S	Range number R 33 W
2. Distance and direction from nearest town or city: 6$\frac{1}{2}$ north of Sublette on Hiway 83, $\frac{1}{2}$ west, $\frac{1}{2}$ south		3. Owner of well: Bob Messerly R.R. or street: Sublette, Ks. 67877 City, state, zip code:			
4. Locate with "X" in section below: 		6. Bore hole dia. 26 in. Completion date 3-14-77 Well depth 600 ft.			
5. Type and color of material		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
		9. Casing: Material steel Height: Above or below surface 12 in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 601 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250			
		10. Screen: Manufacturer's name Johnson Type galv. Dia. 16" Slot/gauze <input type="checkbox"/> Length 20 ft. Set between 560 ft. and 580 ft. Perf: 360-560 ft. and 580-600 ft. Gravel pack? yes Size range of material 1/2" down			
		11. Static water level: <input type="checkbox"/> mo./day/yr. 276 ft. below land surface Date 1-5-77			
(Use a second sheet if needed)		12. Pumping level below land surfaces: 293 ft. after 2 hrs. pumping 900 g.p.m. 298 ft. after 4 hrs. pumping 1200 g.p.m. Estimated maximum yield 1200 g.p.m.			
		13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/> mo./day/yr.			
		14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade			
		15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
		16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		17. Pump: Manufacturer's name Goulds - US Pump Not installed Model number 14JHC HP 200 Volts <input type="checkbox"/> Length of drop pipe 400 ft. capacity 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drlg. Co. 208 Business name License No. Address Box A Garden City, Ks. Signed M. Minter Date 5-20-77 Authorized representative			
		19. Remarks:			
		19. Remarks:			
		19. Remarks:			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

BOYD COUNTY
HASKELL COUNTY
12-9-76

Location: SW 25-28-23 1 mile east of #1 test
Static Water Level- 300'

Test #5

0	4	Top soil
4	67	Brown clay
67	193	Fine to med. sand and gravel
193	201	Brown sandy clay
201	232	Brown clay
232	245	Blue clay
245	411	Fine to med. sand and gravel
411	424	Brown sandy clay
424	456	Fine to med. sand and gravel
456	516	Brown sandy clay
516	530	Fine to med. sand and gravel 100 clay
530	600	Fine to med. sand and gravel with coarse rock
		Loose
600	606	Yellow clay
606	610	"hale

T.D. 600'