

The Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269

P.O. Box A

GARDEN CITY, KANSAS 67846

KENT MESSERLY
Haskell County
July 6, 1982

Location:

Static Water Level:

Test #

0	1	Top Soil
1	63	Brown Clay
63	120	Fine to Medium Sand & Gravel (Loose)
120	180	Medium to Coarse Gravel (Loose)
180	212	Brown Clay
212	280	Fine to Medium Sand & Gravel (Loose)
280	312	Fine to Medium Sand & Gravel 30% Clay
312	365	Fine to Medium Sand & Gravel 10% Clay (Loose)
365	380	Fine to Medium Sand & Gravel 40% Clay
380	402	Brown Clay & White Rock 30% Clay (Tight)
402	421	Fine to Medium Sand & Gravel 10% Clay (Loose)
421	440	Fine to Medium Sand & Gravel 35% Clay (Tight)
440	452	Brown Clay 30% Gravel (Tight)
452	470	Brown Clay 20% Gravel (Tight)
470	490	Brown & White Clay (Tight)
490	500	Gray Brown & Yellow Clay (Hard)

Drilled big hole 440'
6 5/8 Casing 400' Plain
40' Perf