

USE TYPEWRITER OR BALL
POINT PEN—PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Haskell	Fraction NW 1/4 SW 1/4 NE 1/4	Section number 6	Township number T 28 S	Range number R 34 E
2. Distance and direction from nearest town or city: 11 N & 1 E of Ryus, KS Street address of well location if in city:			3. Owner of well: George Taton R.R. or street: City, state, zip code: Satanta, KS 67870		
4. Locate with "X" in section below: N W E S 1 Mile Sketch map: <p>Well Drilled 12/2/75</p>			6. Bore hole dia. 26 in. Completion date 12/4/75 Well depth 479 ft.		
5. Type and color of material See Attachment			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material Steel Height Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36 lbs./ft. Dia. 16 in. to 479 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .219		
			10. Screen: Manufacturer's name W. A. Brown Enterprises Type Leuvered Dia. 16" Slot/gauze 1/8 Length 80 Set between 475-445 ft. and 380-370 ft. 365-345 ft. and 340-320 ft. Gravel pack? Yes Size range of material 3"		
			11. Static water level: 243 ft. below land surface Date 12/4/75		
(Use a second sheet if needed)			12. Pumping level below land surfaces: 296 ft. after <input type="checkbox"/> hrs. pumping 1404 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
			15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: none observed ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
18. Elevation: Flat Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle DRIG & Supply 145 Business name <input type="checkbox"/> License No. <input type="checkbox"/> Address Box 639, Garden City, KS Signed E.L. Bothwell Date 12-29-75 Authorized representative		
			19. Remarks:		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

DRILLERS TEST LOG

CUSTOMERS NAME George Taton DATE 12-5-74
STREET ADDRESS _____ TEST # 1 E. Log Hole 540
CITY & STATE Atanta, Kansas DRILLER Rector
COUNTY Waskell QUARTER NE SECTION 0 TOWNSHIP 20 RANGE 34

LOCATION 1320 South of NW corner of NE 1/4

WELL LOCATION

%	DRILLED from	FOOTAGE Pay to	Description of Strata	Static Water Level Proposed Well Depth
	0	3	Top soil	
	3	105	Brown sandy clay, few sand st.	
	105	170	Sand fine med. coarse; small gravel.	
	170	180	Brown clay, limerock and cemented sand	
	180	190	Sand fine med. coarse; small coarse, med., small gravel. Drilled firm.	
	190	200	Brown clay and limerock st.	
	200	209	Brown sandy clay and sand	
	209	218	Sand fine med. coarse; med, small gravel. Loose.	
			Used water.	
	218	229	Brown clay	
	229	240	Sand fine med. coarse; small coarse, med., small gravel. Loose. Took water.	
55	240	25	265	Brown sandy clay and sand fine to med.
55	265	15	280	Sand fine med. coarse; small coarse, small gravel. Loose. Used lots of water.
	280	Mill.	300	Brown clay, limerock, few sand st.
60	300	24	321	Sand fine med. coarse; small coarse, small gravel. Firm in places. Loose in places.
	324		334	Brown clay and limerock
65	334	46	380	Sand fine med. coarse, small coarse, small gravel.
	380		432	Brown clay
30	432	4	436	Fine sand med. coarse.
	436		440	Brown clay
30	440	37	477	Sand, very fine, med. coarse, hard to catch in screen. Used water. Drilled tight and rough
	477		540	Brown clay and limerock and soapstone and sand st.
		151		TOTAL DEPTH OF WELL 479 Ft.
				Set up facing north
				Pat on the east.

GARDEN CITY, KANSAS HENKLE DRILLING & SUPPLY CO., INC. SUBLETTE, KANSAS
PHONE 276-3278 IRRIGATION HEADQUARTERS PHONE 675-4311
TEST HOLES*****STOCK WELLS*****IRRIGATION AND INDUSTRIAL WELLS*****