

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Haskell	Fraction NE 1/4 NE 1/4 SW 1/4	Section number 11	Township number T 28 S R 34	Range number EW
2. Distance and direction from nearest town or city: 10 north of Sublette on Hiway 83, 7 1/2 west, 3/4 north.				3. Owner of well: John T Farms R.R. or street: Satanta, Ks. 67870 City, state, zip code:		
4. Locate with "X" in section below: <div style="text-align: center;">N 1 Mile W E S 1 Mile</div> Sketch map:				6. Bore hole dia. 26 in. Completion date 10-16-76 Well depth 426 ft.		
5. Type and color of material				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material steel Height: Above 12 in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 427 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250		
				10. Screen: Manufacturer's name Johnson Type galv. Dia. 16" Slot/gauge <input type="checkbox"/> Length 40 ft. Set between 365 ft. and 405 ft. Perf: 320-365 ft. and 405-426 ft. Gravel pack? yes Size range of material 2" down		
				11. Static water level: <input type="checkbox"/> mo./day/yr. 331 ft. below land surface Date 10-6-76		
(Use a second sheet if needed)				12. Pumping level below land surfaces: 380 ft. after 3 hrs. pumping 1100 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1100 g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
				15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 20 ft.		
				16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds - US Pump Model number 12 JHC HP 200 Volts <input type="checkbox"/> Length of drop pipe 400 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name License No. Box A Garden City, Ks. Address 7-25- Signed [Signature] Date 7-25- Authorized representative [Signature] Form WWC-5		
				19. Remarks:		

Forward the white, blue and pink copies to the Department of Health and Environment

Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

JOHN T FARMS
HASKELL COUNTY
9-9-76

Location: S. 11-28-34 24 miles south of Garden City, on 83
Highway 7 1/2 west 2/10 miles north 50 Ft. in field
Static Water Level- 311'

Test #5

0	4	Top soil
4	22	Brown clay
22	61	Brown sandy clay
61	82	Fine to med. sand and gravel 10% clay
82	126	Fine to med. sand and gravel
126	141	Coarse rock
141	173	Fine to med. sand and gravel
173	188	Brown stks. of clay with loose rock
188	200	Yellow sticky clay
200	233	Fine to med. sand and gravel 20% clay
233	304	Fine to med. sand and gravel
304	329	Fine to med. sand and gravel 10% clay
329	426	Fine to med. sand and gravel
426	485	Brown sandy clay brown clay