


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

28 34 W
28 34 W 20 NE NE SE
T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Haskell	Township name	Fraction NE, NE, SE	Section number 20	Town number T 28 S	Range number R 34 W
Distance and direction from nearest town or city: 6 NW, 5 N, 2E, & 3N of Satanta Street address of well location if in city:				3 Owner of well: Mrs. Olive Alexander Address: Satanta, KS		
Locate with "X" in section below: N  W E S 1 Mile				Sketch map:		
2				4 Well depth: 344 ft. Date of completion 9/16/75 Well diameter 2-7/8 in.		
Type and color of material				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
See Attachment				6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well		
				7 Casing: Material Plastic Weight: above/below Glued <input type="checkbox"/> Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. Diam. 5 in. to 344 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No in. to ft. depth		
				8 Screen: Manufacturer Jet Stream Type Slotted Dia. 5 in. Slot/gauze .0404 Length 30 ft. Set between 344 ft. and 314 ft. 1/4 to 1/8 in. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material		
				9 Static water level: Not Pumped ft. below land surface Date		
				10 Pumping level below land surfaces: Not Test Pumped ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.		
				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
				12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				14 Nearest source of possible contamination: Septic Tank ft. 100 Direction E & SE Type Tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
16 Remarks: elevation Topography: <input type="checkbox"/> Hill Flat <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drilling & Supply Business name License No. 145 Address Box 639 Garden City, KS Signed S.A. [Signature] Date 10-13-75 Authorized representative		

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

DRILLERS TEST LOG

CUSTOMERS NAME Mrs. Olive Alexander DATE 9/8/75
 STREET ADDRESS _____ TEST # 1 Housewell
 CITY & STATE Satanta, KS DRILLER Lee
 COUNTY Haskell QUARTER SE SECTION 20 TOWNSHIP 28 RANGE 34
 LOCATION Approx. 250' west, 200' south of NE corner of SE 1/4

%	DRILLED FOOTAGE			Description of Strata	Static Water Level
	From	Pay	To		Proposed Well Depth
	0		3	Top soil	
	3		70	Brown clay, very few caliche st, few ledges, few sand st.	
	70		90	Sand fine to med coarse, sm, med, lg gravel, used lots of water.	
	90		115	Brown clay & few sand st.	
	115		139	Sand fine to med coarse, sm to med gravel, few large, few cemented ledges, used lots of water.	
	139		155	Brown clay, a lot of sand & gravel st.	
	155		195	Sand fine to med coarse, sm gravel med, few rough ledges, very few clay st, used water.	
	195		205	Brown clay, sand st & ledges	
	205		224	Sand fine to med coarse, sm to med gravel, few rough ledges & clay st.	
	224		245	Brown clay, sand fine to med coarse & some sm to med gravel, few limerock ledges, rough in places.	
	245		252	Sand fine to med coarse, small to med gravel, rough in places.	
	252		275	Brown clay, tan clay, few ledges	
	275		288	Brown clay, sand fine to med coarse, sm to med, mixed	
	288		298	Sand fine to med coarse, small gravel	
	298		312	Brown clay, sand st & ledges	
55	312	18	330	Sand fine to med coarse, few small gravel, few clay st, rough ledges	
	330		333	Brown clay	
50	333	9	342	Sand fine to med coarse, few sm gravel & clay st.	
	342		435	Brown clay, few ledges & few sand st.	
	435		495	Brown clay, few gray st & ledges	
	495		515	Soapstone, yellow st, very hard ledges	
	515		520	Soapstone, yellow st, shale st, very hard	
	0		344	Reamed out test hole to 9 7/8	
				Set 5" Heavy Wall Plastic casing w/cap on bottom	
				344-314 Perf, 314 - 0 Plain	
				Used 9 sacks of Revert, 1 gal. chlorine	
				Gravel Packed up with Henkle A	

ARDEN CITY, KANSAS HENKLE DRILLING & SUPPLY CO., INC. SUBLETTE, KANSAS
 PHONE 276-3276 IRRIGATION HEADQUARTERS PHONE 675-4311
 TEST HOLES*****STOCK WELLS*****IRRIGATION AND INDUSTRIAL WELLS*****