


USE TYPEWRITER OR BALL  
POINT PEN—PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment—Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>Haskell</b>	Fraction <b>SW 1/4 SE 1/4 SW 1/4</b>	Section number <b>26</b>	Township number <b>T 28 S</b>	Range number <b>R 34 E</b>
2. Distance and direction from nearest town or city: <b>6 north of the Sublette Jct., 8 west, 1 1/2 north</b> Street address of well location if in city: <b>1/2 east.</b>			3. Owner of well: <b>Philo Wright</b> R.R. or street: <b>Satanta, Ks. 67870</b> City, state, zip code:			
4. Locate with "X" in section below: 			Sketch map:			
5. Type and color of material			From	To	6. Bore hole dia. <b>26</b> in. Completion date <b>5-31-77</b> Well depth <b>455</b> ft.	
					7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material <b>steel</b> Height: Above or below surface Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>36.87</b> lbs./ft. Dia. <b>16</b> in. to <b>456</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <b>250</b>	
					10. Screen: Manufacturer's name <b>Johnson</b> Type <b>galv.</b> Dia. <b>16"</b> Slot <b>1/8"</b> Length <b>20</b> ft. Set between <b>420</b> ft. and <b>440</b> ft. Perf: <b>200-420</b> ft. and <b>440-455</b> ft. Gravel pack? <b>yes</b> Size range of material <b>3/4" down</b>	
					11. Static water level: <b>260</b> ft. below land surface Date <b>5-17-77</b> mo./day/yr.	
					12. Pumping level below land surfaces: <b>275</b> ft. after <b>2</b> hrs. pumping <b>1100</b> g.p.m. <b>280</b> ft. after <b>4</b> hrs. pumping <b>1600</b> g.p.m. Estimated maximum yield <b>1600</b> g.p.m.	
					13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date	
					14. Well head completion: <b>12</b> inches above grade <input type="checkbox"/> Pitless adapter	
					15. Well grouted? <b>yes</b> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.	
					16. Nearest source of possible contamination: <b>N/A</b> ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					17. Pump: Not installed Manufacturer's name <b>Goulds - US Pump</b> Model number <b>14JHMC</b> HP <b>200</b> Volts Length of drop pipe <b>400</b> ft. capacity <b>1200</b> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
					(Use a second sheet if needed)	
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. (208) <b>Minter-Wilson Drilling Co., Inc.</b> Business name <b>Box A Garden City, Ks.</b> License No. Address Signature <b>[Signature]</b> Date <b>5-30-77</b> Authorized representative				

28 34 26 SW SE SW  
T R Sec

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

# WINTER-WILSON DRILLING CO.

INCORPORATED

Integration  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 270-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

PHILO WRIGHT  
HASKELL COUNTY  
3/28/77

Location: SW 26-28-34 8 miles west of Santa Fe Feeders  
1½ north ¼ east

Static Water Level- 280'

## Test #1

0	4	Top soil
4	42	Brown clay
42	66	Fine to med. sand and gravel
66	81	Med. to coarse gravel
81,	111	Fine to med. sand and gravel
111	126	Med. to coarse gravel
126	212	Fine to med. sand and gravel
212	223	Sandy clay
223	312	Fine to med. sand and gravel
312	321	Clay
321	364	Fine to med. sand and gravel
364	380	Fine to med. sand and gravel 15% clay
380	396	Fine to med. sand and gravel
396	408	Brown sandy clay
408	455	Fine to med. sand and gravel

T.D. 455  
Screen 20  
220' - Plain  
200' - Perf  
20' - Screen  
15' - Perf

455