

1 LOCATION OF WATER WELL		Fraction SW 1/4 SE 1/4 SW 1/4		Section Number 35		Township Number T 28 S		Range Number R 34 EW	
County: Haskell				Distance and direction from nearest town or city? 19 miles east of Olysses, ks.				Street address of well if located within city?	
2 WATER WELL OWNER:		John B. Reimer				Board of Agriculture, Division of Water Resources			
RR#, St. Address, Box #		P.O. Box 114				Application Number: 23511			
City, State, ZIP Code		Saratoga, Ks. 67870							
3 DEPTH OF COMPLETED WELL		538.3 ft.		Bore Hole Diameter		27" in.		538.3 ft. and in. to ft.	
Well Water to be used as:		5 Public water supply		8 Air conditioning		11 Injection well			
1 Domestic 3 Feedlot		6 Oil field water supply		9 Dewatering		12 Other (Specify below)			
2 Irrigation 4 Industrial		7 Lawn and garden only		10 Observation well					
Well's static water level		285 ft. below land surface measured on		June month		11 day		1980 year	
Pump Test Data		Well water was		305 ft. after		36 hours pumping		1100 gpm	
Est. Yield 1500 gpm		Well water was		ft. after		hours pumping		gpm	
4 TYPE OF BLANK CASING USED:		5 Wrought iron		8 Concrete tile		Casing Joints: Glued		Clamped	
1 Steel		3 RMP (SR)		6 Asbestos-Cement		9 Other (specify below)		Welded X	
2 PVC		4 ABS		7 Fiberglass				Threaded.	
Blank casing dia 16" in.		to 299.3 ft.		Dia in.		to ft.		Dia in. to ft.	
Casing height above land surface		12 in.		weight 36.8 lbs./ft.		Wall thickness or gauge No		219	
TYPE OF SCREEN OR PERFORATION MATERIAL:		7 PVC		10 Asbestos-cement					
1 Steel		3 Stainless steel		5 Fiberglass		8 RMP (SR)		11 Other (specify)	
2 Brass		4 Galvanized steel		6 Concrete tile		9 ABS		12 None used (open hole)	
Screen or Perforation Openings Are:		5 Gauzed wrapped		8 Saw cut		11 None (open hole)			
1 Continuous slot		3 Mill slot		6 Wire wrapped		9 Drilled holes			
2 Louvered shutter		4 Key punched		7 Torch cut		10 Other (specify)			
Screen-Perforation Dia 16" in.		to 538.3 ft.		Dia in.		to ft.		Dia in. to ft.	
Screen-Perforated Intervals:		From 299.3 ft. to 538.3 ft.		From ft. to ft.		From ft. to ft.		From ft. to ft.	
Gravel Pack Intervals:		From 10 ft. to 538.3 ft.		From ft. to ft.		From ft. to ft.		From ft. to ft.	
5 GROUT MATERIAL:		1 Neat cement		2 Cement grout		3 Bentonite		4 Other	
Grouted Intervals: From		0 ft. to 10 ft.		From ft. to ft.		From ft. to ft.		From ft. to ft.	
What is the nearest source of possible contamination:		10 Fuel storage		14 Abandoned water well X					
1 Septic tank		4 Cess pool		7 Sewage lagoon		11 Fertilizer storage		15 Oil well/Gas well	
2 Sewer lines		5 Seepage pit		8 Feed yard		12 Insecticide storage		16 Other (specify below)	
3 Lateral lines		6 Pit privy		9 Livestock pens		13 Watertight sewer lines		FIRM	
Direction from well south		How many feet 200		Water Well Disinfected? Yes X		No			
Was a chemical/bacteriological sample submitted to Department? Yes		No X		If yes, date sample					
was submitted month day year		Pump Installed? Yes		No X					
If Yes: Pump Manufacturer's name		Model No.		HP		Volts			
Depth of Pump Intake ft.		Pumps Capacity rated at		gal./min.					
Type of pump:		1 Submersible		2 Turbine		3 Jet		4 Centrifugal	
		5 Reciprocating		6 Other					
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on June month 11 day 1980 year									
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 164									
This Water Well Record was completed on November month 20 day 1980 year under the business name of Houck Bros. Drilling Co. by (signature) M. Beard									
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		FROM TO		LITHOLOGIC LOG		FROM TO		LITHOLOGIC LOG	
		0 2		Surface					
		2 50		Clay and sandy clay					
		50 140		Medium sand					
		140 260		Medium sand w/clay strips					
		260 300		Medium sand					
		300 385		Fine to medium to coarse sand w/clay breakers		15-10-15-17			
		385 425		Fine to medium sand w/clay strips		5-9			
		425 485		Fine sandy, clay strips and sandy clay					
		485 535		Medium sandy clay		10-10-5			
535 580		Clay							
ELEVATION: slope									
Depth(s) Groundwater Encountered 1. 272 ft. 2. ft. 3. ft. 4. ft. (Use a second sheet if needed)									
INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.									

OFFICE USE ONLY

T 28

R 34

E 00

SEC 35

SW 1/4

SE 1/4

SW 1/4