

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Grant	Fraction NE 1/4 SE 1/4 NE 1/4	Section number 4	Township number T 28 S R 35 E/W	Range number
2. Distance and direction from nearest town or city: 7 east, 4 north, 5 east, 1 6/10 north of Ulysses, Ks. Street address of well location if in city:				3. Owner of well: Tom Koehn R.R. or street: RFD 1 City, state, zip code: Ulysses, Ks. 67880		
4. Locate with "X" in section below: 		6. Bore hole dia. <u>9 1/4</u> in. Completion date _____ Well depth <u>520</u> ft. <u>10-13-77</u>				
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Surface		0	2	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Sandy clay		2	75	9. Casing: Material <u>styrene</u> Height: Above or below Threaded <u>galv</u> Surface _____ in. RMP _____ PVC _____ Weight _____ lbs./ft. Dia <u>5</u> in. to <u>460</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <u>320</u>		
Fine to medium sand		75	270	10. Screen: Manufacturer's name <u>Sunflower</u> Type <u>styrene</u> Dia. <u>5"</u> Slot/gauze <u>1/16</u> Length <u>60'</u> Set between <u>460</u> ft. and <u>520</u> ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/4"</u>		
Clay w/fine to medium sand strips		270	520	11. Static water level: _____ mo./day/yr. <u>255</u> ft. below land surface Date <u>10-6-77</u>		
				12. Pumping level below land surfaces: <u>290</u> ft. after <u>5</u> hrs. pumping <u>15</u> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>20</u> g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
				14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <u>18</u> Inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
				16. Nearest source of possible contamination: ft. <u>150</u> Direction <u>north</u> Type <u>sewer</u> Well disinfected upon completion? _____ Yes _____ No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Houck Bros. Drlg. Co. 164 Business name <u>Box 487, Ulysses, Ks.</u> License No. _____ Address _____ Signed <u>M. Beard</u> Date <u>11/21/77</u> Authorized representative		
18. Elevation:	19. Remarks:					
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

28
 350
 4
 NE SE
 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5