


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Grant	Township name Sherman	Fraction NW SW SW	Section number 9	Town number 28 s	Range number 35 w		
Distance and direction from nearest town or city: 4 1/2 north 4 east of Hickok, Kansas			3 Owner of well: Everett Schoonover Address: RR 1 Ulysses, Kansas					
Locate with "X" in section below: 			Sketch map:			4 Well depth: 420.6 ft. Date of completion: 2/15/75 Well diameter: 27 in.		
2 Type and color of material			From		To			
			Surface		0 2		5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
			Sandy clay		2 72		6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well	
			Coarse sand and gravel		72 166		7 Casing: Material steel Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 10 in. Diam. 16 inch Weight 36.8 lbs./ft. 16 in. to 300.43 depth! Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No ___ in. to ___ ft. depth!	
			Brown clay w/sand strips		166 250		8 Screen: Lakewood Manufacturer _____ Type steel Dia. 16 inch Slot/gauze 3/16 Length 2" slot length Set from 300.43 to 420.6 Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/4 to 5/8	
			Coarse sand & gravel w/clay breakers		250 288		9 Static water level: 275.2 ft. below land surface Date 2/15/75	
			Coarse sand & gravel		288 349		10 Pumping level below land surfaces: 313 ft. after 21 hrs. pumping 1200 g.p.m. ___ ft. after ___ hrs. pumping ___ g.p.m. Estimated maximum yield 200 g.p.m.	
			Medium to coarse sand w/clay breakers		349 401		11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
			Sandy clay w/sand strips		401 427		12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade	
							13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From 0 ft. to 10 ft.	
				14 Nearest source of possible contamination: ft. 1/2 mile direction south Type house Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No				
				15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other				
16 Remarks: elevation Plowed pland/file field			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Houck Bros. Drilling Co. 164 Business name 487, Ulysses, Ks. Address _____ Signed M. Beard Date 3/20/75 Authorized representative					
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley								

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5