

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County <u>Crawt</u>	Township name <u>Sherman</u>	Fraction <u>NE 1/4 NE 1/4 SE 1/4</u>	Section number <u>14</u>	Town number <u>285</u>	Range number <u>35W.</u>					
Distance and direction from nearest town or city: <u>North of Ulysses, Ks 14 mile east + 4 mile</u>				3 Owner of well: <u>Roy Schmidt</u>							
Street address of well location if in city:				Address: <u>Ulysses, Ks</u>							
Locate with "X" in section below: N W E S 1 Mile		Sketch map:		4 Well depth: <u>435'</u> ft. Date of completion <u>2-3-75</u> Well diameter <u>9"</u> in.							
2 Type and color of material				From		To					
								5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
				<u>surface.</u>		<u>0</u>		<u>2</u>		6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>	
				<u>clay - yellow</u>		<u>2</u>		<u>40</u>		7 Casing: Material <u>Styrene</u> Height: above <input checked="" type="checkbox"/> Below <input type="checkbox"/> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>36</u> in. Diam. <u>5"</u> Weight <u>320</u> lbs./ft. <u>0</u> in. to <u>435'</u> depth! Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <u> </u> in. to <u> </u> ft. depth!	
				<u>Clay w/ strippy sand</u>		<u>140</u>		<u>220</u>		8 Screen: Manufacturer <u>Sunflower</u> Type <u>Styrene</u> Dia. <u>5"</u> Slot/gauze <u>1/16</u> Length <u>20'</u> Set between <u>415</u> ft. and <u>435</u> ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u>#1</u>	
				<u>fine sand</u>		<u>230</u>		<u>235</u>		9 Static water level: <u>265'</u> ft. below land surface Date <u>2-5-75</u>	
				<u>Clay</u>		<u>235</u>		<u>270</u>		10 Pumping level below land surfaces: <u>270</u> ft. after <u>24</u> hrs. pumping <u>20</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u> </u> g.p.m.	
				<u>fine - medium sand.</u>		<u>370</u>		<u>385</u>		11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>	
				<u>Clay</u>		<u>385</u>		<u>410</u>		12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter unit <input type="checkbox"/> Inches above grade	
				<u>medium sand</u>		<u>410</u>		<u>435'</u>		13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> <u> </u> Depth: From <u>435'</u> ft. to <u>20</u> ft.	
						14 Nearest source of possible contamination: ft. <u>150</u> Direction <u>EAST</u> Type <u>Sewer</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
						15 Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Aermator</u> Model number <u>3079</u> HP <u>2</u> Volts <u>230</u> Length of drop pipe <u>300'</u> ft. capacity <u>20</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
16 Remarks: elevation				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Jim Smith Pump Service</u> <u>160A</u> Business name License No. Address <u>Johnson, Ks</u> Signed <u>Jim Smith</u> Date <u>6-5-75</u> Authorized representative							
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley											