

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Grant	Section SE 1/4 NE 1/4 SW 1/4	Section number 15	Township number T 28 S R 35N	Range number E/W
2. Distance and direction from nearest town or city: 5 East-3 1/2 North-4/10 East of Hickok Street address of well location if in city:			3. Owner of well: C. R. DeVatz R.R. or street: Cherry Vale Kansas 67335 City, state, zip code:		
* Locate with "X" in section below: N W E S 1 Mile 1 Mile		Sketch map: SE 1/4 NE 1/4 SW 1/4 4 East X 3 1/2 North Hickok 5 East		6. Bore hole dia. 5 1/2 in. Completion date _____ Well depth 26 ft.	
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
Surface & Fine Sand		0	15	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Brown Clay		15	30	9. Casing: Material steel Height: Above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface 12 in. RMP _____ PVC _____ Weight 34.25 lbs./ft. Dia. 1 1/2 in. to 5 1/2 ft. depth Well Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. _____	
Sand- medium to Coarse- Cemented Strips		30	295	10. Screen: Manufacturer's name Johnson Fittings: *See Remarks Type Galvanized Dia. 1 1/2 Slot/grooves 100x100 Length 50 Set between 360 ft. and 470 to 500 ft. _____ ft. and _____ ft. Gravel pack? yes Size range of material 1/2 down	
Sand & Brown Clay 60%		295	330	11. Static water level: _____ mo./day/yr. 260 ft. below land surface Date 5/6/76	
Brown Clay		330	360	12. Pumping level below land surfaces: 330 ft. after 2 hrs. pumping 900 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.	
Sand & some Brown Clay 80%		360	382	13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____	
Brown Clay		382	435	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade	
Brown Clay & strips of Sand 25%		435	450	15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite _____ Concrete _____ Depth: From 0 ft. to 10 ft.	
Brown Clay & some Dakota		450	472	16. Nearest source of possible contamination: ft. _____ Direction In Field Type none	
Dakota (Loose)		472	490	Well disinfected upon completion? _____ Yes <input checked="" type="checkbox"/> No	
Lava rock & fine Brown Sand (Loose)		490	515	17. Pump: _____ Not installed Manufacturer's name Goulds Model number 12 J HP 200 Volts _____ Length of drop pipe 460 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Blue Shale		515	525	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. K.I. Drilling Co., Inc. 263 Business name License No. Address Box 669 Ulysses, Ks. Signed M. Joyce Brooks Date 5/25/65 Authorized representative	
18. Elevation:		(Use a second sheet if needed)		20. Water well contractor's certification:	
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks: Drilling Sub Contracted to Minter Wilson Drilling. *Lakewood- Slot- 125x66 set between 260&360, 380 to 470, & 500 to 515.		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. K.I. Drilling Co., Inc. 263 Business name License No. Address Box 669 Ulysses, Ks. Signed M. Joyce Brooks Date 5/25/65 Authorized representative	

T 28 S 35N E 15 SE 1/4 SW 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5