

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Grant	Fraction NW¹/₄ SW¹/₄ SE¹/₄	Section number 22	Township number T28^S	Range number R 35W E/W
2. Distance and direction from nearest town or city: 5 miles East, 2 North, 1/4 East & 1/8 North Street address of well location if in city: of Hickok			3. Owner of well: Vernon Koehn R.R. or street: Route 1 City, state, zip code: Ulysses, Kansas 67880			
Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 26 in. Completion date 6-21-76 Well depth 506 ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Surface and fine Sand		0	20	9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 34 1/2 lbs./ft. Dia. 16 in. to 506 ft. depth, <input checked="" type="checkbox"/> Well Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth, gage No. <input type="checkbox"/>		
Sand and crock		20	120	10. Screen: Manufacturer's name Johnson Type Galvanized Dia. 16 Slot/gauge 100x100 Length 80 Set between 350 & 380 ft. and 440 to 490 ft. *See remarks, ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> yes Size range of material 1/2" down		
Sand & some Brown clay		120	180	11. Static water level: <input type="checkbox"/> mo./day/yr. 262 ft. below land surface Date 6-21-76		
Sand and fine sand		180	380	12. Pumping level below land surfaces: 283 ft. after 6 hrs. pumping 1000 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1000 g.p.m.		
Brown and Gray Clay		380	400	13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
Gray clay & some fine Sand		400	460	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
Fine lava sand & Dakota (Loose)		460	500	15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input checked="" type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
Lost Circulation at 500 Foot.				16. Nearest source of possible contamination: ft. NONE IN FIELD Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Used Model number <input type="checkbox"/> HP 150 Volts <input type="checkbox"/> Length of drop pipe 480 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		(Use a second sheet if needed)		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. K. I. Drilling Co., Inc. 263 Business name License No. <input type="checkbox"/> Address P. O. Box 669 Ulysses, Ks Signed M. Joyce Brasher Date 07/21/76 Authorized representative		
19. Remarks: Drilling Sub-Contracted to Minter Wilson Garden City, Kansas *Lakewood Perferated- Slot-.125x66 set between 300 & 350, 380 to 440, & 490						

28
 25
 22
 1/4 NW 1/4 SE
 Sec

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5