

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment (Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Grant County	Fraction 1/4 1/4 NW 1/4	Section number 29	Township number T 28 S R	Range number 35 EW
2. Distance and direction from nearest town or city: 9 1/2 East of Ulysses on US 160, 1 3/4 North Street address of well location if in city:			3. Owner of well: Les King (KI) R.R. or street: 305 N Baughman City, state, zip code: Ulysses, KS 67880		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 6 5/8 in. Completion date 11-31-77 Well depth 455 ft.	
		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 1 ft. in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 17.3 lbs./ft. Dia. 6 5/8 to 455 ft. depth; Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth; gage No. .250	
5. Type and color of material			From	To	10. Screen: Manufacturer's name Johnson
					Type Johnson Galv. Dia. 100-6 5/8
					Slot/gauze 0-300 Plain Length 300-360 Perf.
					Set between 360-410 Screen and 410-430 Perf.
					430-440 Screen and 440-455 Perf. ft.
					Gravel pack? yes Size range of material 1/2 to 5/8
					11. Static water level: 257 ft. below land surface <input checked="" type="checkbox"/> Date 7-7-77 mo./day/yr.
					12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.
					13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 11-31-77 mo./day/yr.
					14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter _____ inches above grade
					15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
					16. Nearest source of possible contamination: ft. 600 Direction Sesspool Northwest Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
			(Use a second sheet if needed)		
18. Elevation:		19. Remarks:			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling Co. 208 Business name License No. _____ Address Box A, Camden City, KS 67846 Signed <i>[Signature]</i> Date 6/27/79 Authorized representative					

T
R
S
W
E
M
Sec
1/4
NW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The
Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67540

October 7, 1977

Les King
Grant County

Location: NW $\frac{1}{4}$ 29-28-35 West $\frac{1}{2}$ of $\frac{1}{4}$ East of Ulysses to first
road East of Mobil Plant, $1\frac{1}{2}$ miles North, $\frac{1}{2}$ East,
Approx. 85' West of existing well

Static Water Level - 257

Test #1

0	1	Top Soil
1	32	Brown Clay
32	55	Fine to med. sand
55	65	Brown Clay (tight)
65	83	Fine to med. sand & gravel (loose)
83	97	Brown Sandy Clay 35% Gravel (loose)
97	123	Fine to med. sand & gravel 10% Clay (loose)
123	140	Brown Clay
140	155	Fine to med. sand & gravel (tight)
155	172	Brown Clay (tight)
172	195	Fine to med. sand & gravel (loose)
195	208	Brown Clay
208	215	Fine to med. sand (fairly loose)
215	230	Brown Clay streaks of sand 30% (tight) (hard streaks)
230	239	Fine to med. sand & gravel (loose)
239	297	Brown Clay
297	332	Fine to med. sand & gravel (loose)
332	340	Fine to med. sand & gravel 10% Clay & Brown rock (hard)
340	367	Fine to med. sand & gravel (loose) (Small hard streaks) (streaks of coarse gravel)
367	415	Fine to med. sand & gravel (loose)
415	432	Brown Sandy Clay
432	441	Fine to med. sand & fine gravel 10% Clay (loose)
441	453	Brown Sandy Clay (Small streaks of fine to med. sand & fine gravel 30% (Fairly loose)
453	485	Brown Gray & Yellow Clay (tight)

T. D. 455