


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Grant	Township name Sherman	Fraction SE SE NW	Section number 31	Town number 28 S	Range number 36 W
Distance and direction from nearest town or city: 1 mile east 1/2 north of Hickok, Ks.				3 Owner of well: Larry Kepley, Trustee for Kansas Christian Home, Inc. Ulysses, Kansas 67880		
Locate with "X" in section below: 				Sketch map: 4 Well depth: 482 ft. Date of completion: 2/28/75 Well diameter 27 in. 5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary 6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/> _____ 7 Casing: Material steel Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 16" Weight 36.86 lbs./ft. 0 in. to 214 ft depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No _____ in. to _____ ft. depth!		
2 Type and color of material				From	To	
Surface				0	2	
Sandy clay				2	45	
Medium to coarse sand and gravel				45	58	
Sandy clay w/sand strips				58	127	
Brown gummy clay				127	160	
Blue and brown gummy clay				160	262	
Embedded sand & clay				262	294	
Medium to coarse sand				294	322	
Medium to coarse sand w/small clay breakers				322	388	
Medium to coarse sand w/large clay breakers				388	400	
Fine to medium sand w/large clay breakers				400	417	
Blue & brown shale w/very fine sand				417	469	
Blue & brown shale and sandrock loose				469	483	
Blue & brown shale tight						
(use a second sheet if needed)						
16 Remarks: elevation Wheat field				9 Static water level: 268.6 ft. below land surface Date 2/26/75 10 Pumping level below land surfaces: 310 ft. after 12.7 hrs. pumping 1300 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1500 g.p.m. 11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____ 12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade 13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From 0 ft. to 12 ft. 14 Nearest source of possible contamination: ft. 3/4 mile southwest house Direction type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No 15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Houck Bros. Drlg. Co. 164 Business name License No. Address Box 487 Ulysses, Kas Signed Marlie Beald Date 3/28/75 Authorized representative		

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5