

The
Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

Hollis Bullock
Grant County
3/14/95

Location: NW $\frac{1}{4}$ 2-28-36 - From Hickok - 6 Miles North,
 $\frac{1}{2}$ Mile East - South side

Static Water Level - 330'

Test #1

0' to 2' ^{Q1} Top soil
2' to 78' ⁰⁴ Brown sandy clay
78' to 118' ⁰⁸ Fine to medium sand and gravel
118' to 126' ⁰¹ Brown clay
126' to 142' ⁰⁸ Fine to medium sand and gravel-10% clay
142' to 157' ⁰⁴ Brown sandy clay
157' to 190' ⁰⁸ Fine to medium sand - 15% clay
190' to 202' ⁰⁴ Brown sandy clay
202' to 216' ⁰¹ Blue yellow clay mixed
216' to 230' ⁰⁸ Fine to medium sand - 10% clay - tight
230' to 245' ⁰¹ Blue yellow clay
245' to 277' ⁰⁸ Fine to medium sand clay strip mixed
277' to 310' ⁰⁸ Fine to medium sand and gravel
310' to 333' ⁰¹ Blue brown yellow clay
333' to 356' ⁰⁸ Fine to medium sand and gravel - tight
356' to 370' - Brown clay
370' to 392' ⁰¹ Brown blue clay mixed
392' to 411' - Fine to medium sand and gravel-hard spot
and tight
411' to 417' - Fine to medium sand and gravel - white
rock mixed - very hard pull down
417' to 459' ⁰⁸ Fine to medium sand and gravel
459' to 473' ⁰¹ Brown clay
473' to 481' ⁰⁸ Fine to medium sand and gravel
- small clay strip mixed
481' to 502' - Brown clay
502' to 516' ⁰¹ Brown yellow clay
516' to 530' ¹⁹ Shale - hard pull down