


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Grant	Township name	Fraction SW, SW, NE	Section number 6	Town number T285	Range number R37W
Distance and direction from nearest town or city: Approx. 3.5 N & 2.5 W from Ulysses Street address of well location if in city:				3 Owner of well: Ernest R. Gall Address: 1561 Curtis Ave Manhattan Beach, Calif		
Locate with "X" in section below: N  W X E S 1 Mile		Sketch map:		4 Well depth: 585' ft. Date of completion 25 Apr 75 Well diameter 28 in.		
2 Type and color of material Well drilled near site of TH 3-74 (see attached), which is 390' N & 224' E. of SW cor of Sec 6, 28-37, Grant Co.				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well		
				7 Casing: Material steel Height: above below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 16 in. to 585 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No _____ in. to _____ ft. depth		
				8 Screen: Manufacturer L.B. Foster Type Mill-slot Dia. 16" Slot/gauze 1/8" Length 367' Set between 218 ft. and 585 ft. Fittings: 1/6 to 5 mm Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material _____		
				9 Static water level: 206 ft. below land surface Date 15 Apr 75		
				10 Pumping level below land surfaces: 376 ft. after 2 hrs. pumping 383 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 540 g.p.m.		
				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
				12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From 0 ft. to 10 ft.		
				14 Nearest source of possible contamination: Unk ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
(use a second sheet if needed)				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Peerless Model number _____ HP 100 Volts _____ Length of drop pipe 480 ft. capacity 625 g.m.p. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne-Western Co 150 Business name License No. Address Garden City Signed R. E. Vincent Date 14 May 75 Authorized representative		

TEST HOLE REPORT

Layne-Western Company, Inc.



WATER SUPPLY SERVICES SINCE 1924
TEST DRILLING • WATER WELLS • PUMPS

Contract Name Ernest Gall

Job No. K-467 Date 9-25-74

City Manhattan Beach State Calif.

TEST HOLE
No. 3-74

Driller Parson

Location of Test Hole 200' W. of test hole
2-74 or 390' north & 224' east of SW
corner of

Elevation of Test Hole _____

Static Water Level _____

Measured _____ Hours After Completion

1/4 NE 1/4 Sec. 6 of T 28S

R 37W, Grant Co., Kansas

From	To	Description of Strata	Water Bearing
0	2	Top soil	
2	25	Tan clay	
25	54	Fine to coarse sand some gravel	
54	108	✓ Tan clay	
108	182	Blue clay	
182	200	✓ Tan & green sandy clay	
200	217	Very fine to med. sand with white & tan clay mixed	
217	224	✓ White & tan clay	
224	227	Limestone & sand mixed	
227	244	Fine to coarse sand med. to coarse gravel	10
244	250	✓ Tan clay with sand stks.	
250	276	Fine to coarse sand med. gravel med. loose	27
276	290	✓ Tan clay sticky	
290	310	Very fine to med. sand mixed with clay	10
310	325	Limestone fine sand & white clay mixed	
325	332	Very fine to med. sand loose	7
332	350	Dokota clays some stks. of sandstone	
350	373	Dokota siltstone med. hard	
373	383	Yellow siltstone & Dokota clay	
383	512	Black Shale with hard lenses	

Remarks:

