


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Grant	Township name	Fraction E$\frac{1}{2}$, SE$\frac{1}{4}$, SW$\frac{1}{4}$	Section number 9	Town number T 28 S	Range number R 37 W					
Distance and direction from nearest town or city: 3 N. & $\frac{1}{2}$ W. of Ulysses Street address of well location if in city:				3 Owner of well: Dale Stevenson Address: Ulysses, KS							
Locate with "X" in section below: N  W E S 1 Mile			Sketch map:			4 Well depth: 308 ft. Date of completion 5-7-75 Well diameter 12$\frac{1}{4}$ in.					
2 Type and color of material			From To			5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary					
						6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/> _____					
						7 Casing: Material Plastic Height: above below Threaded <input checked="" type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. Diam. _____ Weight _____ lbs./ft. _____ 6 5/8 in. to 308 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No _____ in. to _____ ft. depth!					
						8 Screen: Manufacturer Jess & Lowell Type Slotted Dia. 6 5/8" Slot/gauze .060 Length 40 ft. Set between 290 ft. and 300 ft. Fittings: 260' & 280', 240' & 250' Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/8"					
						9 Static water level: Approximately 200' _____ ft. below land surface Date _____					
						10 Pumping level below land surfaces: not test pumped _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.					
						11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____					
						12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade					
						13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.					
						14 Nearest source of possible contamination: Septic ft. 100 Direction West Type lank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
(use a second sheet if needed)						15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
						17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drilling & Supply 145 Business name _____ License No. _____ Address Box 639, Garden City, KS Signed James H. Henkle Date 5/21/75 Authorized representative					
16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley Flat											

DRILLERS TEST LOG

CUSTOMERS NAME Dale Stevenson DATE 8-5-78
 STREET ADDRESS _____ TEST # Houswell #2
 CITY & STATE Wynona, MN DRILLER Livingston
 COUNTY Grant QUARTER NE SECTION 9 TOWNSHIP 28 RANGE 37

LOCATION _____

%	DRILLED FOOTAGE		Description of Strata	WELL LOCATION
	From	Pay to		Static Water Level Proposed Well Depth
	0	2	Top soil	
	2	10	Clay & fine sand	
	10	210	Brown sandy clay & fine sand st.	
75	210	240	Sand fine to med. coarse, small to large gravel	
	240	260	Brown sandy clay	
70	260	275	Sand fine to med. coarse, small to med. gravel	
	275	295	Brown sandy clay & sand to small sand.	
	295	330	Brown clay	
	330	340	Sandstone - lost circulation	