

1 LOCATION OF WATER WELL  
 County: Grant Fraction SE 1/4 SE 1/4 SW 1/4 Section Number 17 Township Number T 28 S Range Number R 37 **BW**  
 Distance and direction from nearest town or city? from hwy. jct at Ulysses, Ks. 1 1/2 west, 2 north Street address of well if located within city?

2 WATER WELL OWNER: Bill Rogers  
 RR#, St. Address, Box #: Box 492 Board of Agriculture, Division of Water Resources  
 City, State, ZIP Code: Ulysses, Ks. 67880 Application Number:

3 DEPTH OF COMPLETED WELL: 395 ft. Bore Hole Diameter: 9 7/8 in. to 395 ft., and          in. to          ft.  
 Well Water to be used as:  
 1 Domestic 3 Feedlot 5 Public water supply 8 Air conditioning 11 Injection well  
 2 Irrigation 4 Industrial 6 Oil field water supply 9 Dewatering 12 Other (Specify below)  
fish pond  
 Well's static water level: 240 ft. below land surface measured on August month 29 day 1979 year  
 Pump Test Data: Well water was 330 ft. after 24 hours pumping, 32 gpm  
 Est. Yield 35 gpm: Well water was          ft. after          hours pumping          gpm

4 TYPE OF BLANK CASING USED:  
 1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile Casing Joints: Glued  Clamped   
 2 PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below) & riveted  Welded   
 7 Fiberglass Threaded   
 Blank casing dia: 5 in. to 245 ft., Dia 5 in. to 365 ft., Dia          in. to          ft.  
 Casing height above land surface: Pitless unit in., weight          lbs./ft. Wall thickness or gauge No. 320  
 TYPE OF SCREEN OR PERFORATION MATERIAL:  
 1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 10 Asbestos-cement  
 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 11 Other (specify)           
 12 None used (open hole)  
 Screen or Perforation Openings Are:  
 1 Continuous slot 3 Mill slot 5 Gauzed wrapped 8 Saw cut 11 None (open hole)  
 2 Louvered shutter 4 Key punched 6 Wire wrapped 9 Drilled holes 10 Other (specify)           
 7 Torch cut  
 Screen-Perforation Dia: 5 in. to 265 ft., Dia 5 in. to 395 ft., Dia          in. to          ft.  
 Screen-Perforated Intervals: From 245 ~~265~~ ft. to 265 ft., From          ft. to          ft.  
 From 365 ft. to 395 ft., From          ft. to          ft.  
 Gravel Pack Intervals: From 145 ft. to 395 ft., From          ft. to          ft.  
 From          ft. to          ft., From          ft. to          ft.

5 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other  
 Grouted Intervals: From 0 ft. to 10 ft., From          ft. to          ft., From          ft. to          ft.  
 What is the nearest source of possible contamination:  
 1 Septic tank 4 Cess pool 7 Sewage lagoon 10 Fuel storage 14 Abandoned water well  
 2 Sewer lines 5 Seepage pit 8 Feed yard 11 Fertilizer storage 15 Oil well/Gas well  
 3 Lateral lines 6 Pit privy 9 Livestock pens 12 Insecticide storage 16 Other (specify below)  
field  
 Direction from well:          How many feet         ? Water Well Disinfected? Yes  No   
 Was a chemical/bacteriological sample submitted to Department? Yes  No  If yes, date sample was submitted          month          day          year: Pump Installed? Yes  No   
 If Yes: Pump Manufacturer's name: Goulds Model No. 25 EL HP 5 Volts 230  
 Depth of Pump Intake: 357 ft. Pumps Capacity rated at 25 ~~32~~ gal./min.  
 Type of pump: 1 Submersible  2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other

6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on September month 30 day 1979 year  
 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 164  
 This Water Well Record was completed on April month 8 day 1980 year under the business name of Houck Bros. Drilling Co. by (signature) M. Beard

7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:	FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG
		0	2	Surface		
	2	102	Brown sandy clay w/very fine sand strips			
	102	210	Blue & brown clay w/fine sand strips			
	210	241	Sandy clay w/fine sand strips			
	241	262	Medium to coarse <del>XXXX</del> sand w/clay breakers			
	262	373	Sandy clay w/fine sand			
	373	395	Medium to coarse sand w/clay breakers			
ELEVATION:	slope					

Depth(s) Groundwater Encountered 1. 240 ft. 2.          ft. 3.          ft. 4.          ft. (Use a second sheet if needed)

INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.

OFFICE USE ONLY  
T  
R  
SEC  
17  
SE 1/4  
SE 1/4  
SW 1/4