

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>Grant</b>	Fraction <b>SE 1/4 NW 1/4 NW 1/4</b>	Section number <b>28</b>	Township number <b>T 28 S R 37 E 11</b>	Range number <b>37</b>
2. Distance and direction from nearest town or city: <b>3/4 W of Ulysses</b> Street address of well location if in city:				3. Owner of well: <b>Earl Fort</b> R.R. or street: <b>811 North Simpson</b> City, state, zip code: <b>Ulysses, KS</b>		
4. Locate with "X" in section below: N W E S 1 Mile Sketch map: 				6. Bore hole dia. <b>1 1/2</b> in. Completion date <b>10-15-75</b> Well depth <b>390</b> ft.		
5. Type and color of material				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
See Attachment				9. Casing: Material <b>Plstc</b> Height: <b>Above</b> or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <b>12</b> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. <b>65/8</b> to <b>390</b> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. _____		
				10. Screen: Manufacturer's name <b>Jet Stream</b> Type <b>Slotted</b> Dia. <b>6-5/8"</b> Slot/gauze <b>.040</b> Length <b>50'</b> Set between <b>390</b> ft. and <b>360</b> ft. <b>280 &amp; 270</b> ft. and <b>190 &amp; 180</b> ft. Gravel pack? <b>Yes</b> Size range of material <b>3"</b>		
				11. Static water level: <b>Not Pumped</b> no./day/yr. _____ ft. below land surface Date _____		
				12. Pumping level below land surfaces: <b>Not Test Pumped</b> _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
				14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter _____ Inches above grade		
				15. Well grouted? <b>Yes</b> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.		
				16. Nearest source of possible contamination: ft. <b>1/2 M</b> Direction <b>W</b> Type <b>Septic Tank</b> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				(Use a second sheet if needed)		
18. Elevation: <b>Flat</b> Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Henkle DRIG &amp; Supply 145</b> Business name License No. _____ Address <b>Box 639, Garden City, KS</b> Signed <b>E. L. Bathune</b> Date <b>11-2-75</b> Authorized representative		

28  
32  
28  
SE 1/4 NW 1/4  
1/4  
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

DRILLERS TEST LOG

CUSTOMERS NAME Earl Fort DATE 10-13-75  
 STREET ADDRESS 811 North Simpson TEST # Housewell  
 CITY & STATE Ulysses, KS DRILLER Livingston  
 COUNTY Grant QUARTER NW SECTION 28 TOWNSHIP 28 RANGE 37

LOCATION From Air Port, 1 west, 1/2 south & 900' east (approx)

%	DRILLED FOOTAGE			Description of Strata	WELL LOCATION	
	From	Pay	To		Static Water Level	Proposed Well Depth
	0		10	Sand & Clay st.		
	10		30	Sandy clay & fine sand st.		
	30		100	Brown clay		
	100		127	Brown clay & few limerock ledges		
	127		180	Blue, gray & brown clay & few fine sand st.		
40	180	20	200	Sand fine to small & clay st.		
	200		270	Brown sandy clay & fine sand st.		
70	270	10	280	Sand fine to med coarse, small to med gravel		
	280		358	Brown sandy clay & limerock ledges		
Good	358	09	367	Brown rock & sandstone, used water.		
Fair	367	21	388	Soapstone & sandstone, used water.		
	388		398	Weathered shale & dakota st.		
	398		480	Weathered shale & limestone ledges		
				TOTAL DEPTH OF WELL 390'		
				Set up face south		
				Dig pit on the west		
				6 5/8" Plastic Casing		
				390 - 360 Perf.		
				360 - 280 Plain		
				280 - 270 Perf.		
				270 - 190 Plain		
				190 - 180 Perf.		
				190 - 0 Plain		
				Henkle A Gravel Pack		
				6 sacks of Revert		
				1 gal of Chlorine		

ARDEN CITY, KANSAS HENKLE DRILLING & SUPPLY CO., INC. SUBLETTE, KANSAS  
 HONE 276-3278 IRRIGATION HEADQUARTERS PHONE 675-4311

EST HOLES\*\*\*\*\*STOCK WELLS\*\*\*\*\*IRRIGATION AND INDUSTRIAL WELLS\*\*\*\*\*