

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

*Sketch*

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>Grant</b>	Fraction SW $\frac{1}{4}$ NW $\frac{1}{4}$ NW $\frac{1}{4}$	Section number <b>32</b>	Township number T <b>28</b> S	Range number R <b>37</b> E <b>W</b>
2. Distance and direction from nearest town or city: Street address of well location if in city:				3. Owner of well:		
3 <sup>74 feet</sup> / <sub>4</sub> miles west <del>1/8</del> mile south of <b>Ulysses, Ks.</b>				<b>Earl Vanderpool</b> <b>Ulysses, Kansas 67880</b>		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>9.25</u> in. Completion date <u>11-19-76</u> Well depth <u>340</u> ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Surface		0	2	9. Casing: Material <u>styrene</u> Sight <u>Above</u> or below Threading <u>Welded</u> Surface <u>12</u> in. RMP <u>5</u> PVC <u>270</u> Weight <u>        </u> lbs./ft. Dia. <u>5</u> in. to <u>270</u> ft. depth; Wall Thickness: inches or Dia. <u>        </u> in. to <u>        </u> ft. depth; gage No. <u>.320</u>		
Brown clay		2	145	10. Screen: Manufacturer's name <u>Sunflower</u> Type <u>styrene</u> Dia. <u>5"</u> Slot/gauze <u>1/16</u> Length <u>70</u> Set between <u>270</u> ft. and <u>340</u> ft. <u>        </u> ft. and <u>        </u> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>No. 1</u>		
Brown clay w/fine sand strips		145	240	11. Static water level: <u>NA</u> ft. below land surface Date <u>11-21-76</u> mo./day/yr.		
Medium to coarse sand w/clay strips		240	275	12. Pumping level below land surfaces: <u>NA</u> <u>        </u> ft. after <u>        </u> hrs. pumping <u>        </u> g.p.m. <u>        </u> ft. after <u>        </u> hrs. pumping <u>        </u> g.p.m. Estimated maximum yield <u>        </u> g.p.m.		
Fine sand w/clay strips		275	340	13. Water sample submitted: <u>        </u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u>        </u>		
Fine sand		340	360	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <u>12</u> Inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
				16. Nearest source of possible contamination: <u>75</u> ft. Direction <u>East</u> Type <u>Sewer line</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u>        </u> Model number <u>        </u> HP <u>        </u> Volts <u>        </u> Length of drop pipe <u>        </u> ft. capacity <u>        </u> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				(Use a second sheet if needed)		
18. Elevation:	19. Remarks:		20. Water well contractor's certification:			
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	Mr. Vanderpool is a pump man and he put the pump in the well and did not take the static water level or the g.p.m.		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Houck Bros. Drilling Co. 164</b> Business name <u>        </u> HP <u>        </u> Volts <u>        </u> Address <u>Box 487, Ulysses, Ks.</u> License No. <u>        </u> Signed <u>M. Beard</u> Date <u>11/19/76</u> Authorized representative			

2.88  
 3.76  
 3.2  
 SW NW NE  
 1/4 1/4 1/4  
 Sec

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5