WATER WELL RECORD KSA 82a-1201-1215

		П	
ldot		\perp	
T	R	EW	sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health (Water Well Contractors) Forbes—Bldg. 740 Topeka, Kansas 66620

1 Location of well:	County Grant	Township name	Fraction NE ¹ 4, NE ¹ 4, SW4		n number 24		Town number	Range number	
Distance and direction from nearest town or city: 1 mi. N., 3½ mi. West, ½ mi. N. & 100 Ft. W. Street address of well location if in city: of Ulysses						C. E. Battin 409 South Maxwell Ulysses, Kansas 67880			
Locate with "X" in section below: Sketch map:							4 Well depth:550 ft. Date of completion128 Well diameter26 in. 5 Cable tool Rotary Driven Dug		
West West						Hollow rod Jetted Bored Reverse rotary			
					sses				
2	•	e and color of material		From	To	in. to ft. depth			
Type and color of material						8 Screen: Manufacturer Johnson			
Surface & Brown Clay				0	15	Type Galvanized Dia. 16 in. Slot/see-100X100 Length 60 ft. Set between 355 ft. and 375 ft. 455 & 49 Fittings: * See Remarks Gravel pack X Yes No Size range of material 200			
Brown Clay				15	45				
Fine to Medium Sand				45	75	9 Static water level: 170 ft. below land surface Date 1-30-76			
Brown Clay			75	247					
Coarse Sand				247	280	10 Pumping level below land surfaces: 233 ft. after 2 hrs. pumping 650 g.p.m.			
Brown Clay					288	ft. after hrs. pumping g.p.m. Estimated maximum yield 1000 g.p.m.			
Coarse Sand with Cemented Strips					318	11 Water sample submitted:			
Brown Clay					345	12 Well head completion: Pitless adapter Inches above grade			
Coarse Sand, Gravel & 5 ft. Clay Strip					375	13 Well grouted? X Yes No			
Blue Shale					458		Neat cement X Bentoni		
Blue Shale & Sandstone (Took Water)					503	14 N	earest source of possible co	ntarination	
Blue Shale				503	510	<u>w</u>	ell disinfected upon comple	etion? Yes X No	
Sandstone			510	533		anufacturer's name	Not installed		
Rock				533				HP _200_ Volts t. capacit] 200 g.m.p.	
Sandstor	ne			537	550	1 —	pe:] Submersible	Turbine	
		ed Bed - (565))		560] Jet] Certrifugal	Reciprocating Other	
Topography: Contracted to: Minter-Wilson Drilling Co. License #208 Garden City, Kansas 67846 Slope Lakewood Perf Slot - 125 X 66 Slope Set Between 285' & 355' and 375' & 455' Upland Valley Valley						17 Water well contractor's certification:			

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5