



**DRILLERS TEST LOG**

CUSTOMERS NAME A. C. Anderson DATE 6-3-75  
 STREET ADDRESS \_\_\_\_\_ TEST # 2 E-Log 605 ft.  
 CITY & STATE Johnson, KS DRILLER Rector  
 COUNTY Stanton QUARTER NE SECTION 18 TOWNSHIP 28 RANGE 39

LOCATION 200 ft. north of Test #1

**WELL LOCATION**

%	DRILLED FOOTAGE		Description of Strata	Static Water Level <u>170 ft.</u> Proposed Well Depth
	from	Pay to		
	0	3	Top soil	
	3	30	Brown sandy clay & fine sand.	
	30	60	Brown clay & caliche.	
	60	73	Sand fine to med coarse.	
	73	160	Brown clay & few sand, sticky (clay)	
	160	170	Brown, sandy clay & sand.	
	170	180	Sand fine to med coarse, small gravel & clay sts.	
	180	210	Brown clay & sand sts.	
50	210	20 240	Sand fine to med coarse, small gravel & small clay sts, loose, took water.	
	240	260	Brown clay & caliche.	
55	260	20 280	Sand fine to med coarse, med to small gravel, few white & tan rock, loose, used water.	
	280	300	Sand med coarse, brown clay & broken white rock.	
60	300	19 319	Sand fine to med coarse, small gravel, loose, used water.	
	319	350	Brown sandy clay & sand med coarse.	
30	350	15 365	Brown clay, broken white rock, used water.	
45	365	15 380	Sand med coarse, small gravel, brown rock, broken white rock, & clay.	
	380	390	Brown sandy clay & brown sandstone, & sand.	
	390	440	Brown clay (sticky) & few rock ledges.	
fair	440	20 460	Blue shale & few hard ledges & sandstone st.	
very good	460	142 602	Blue shale, brown & white sandstone, loose, in places, firm in places, used water.	
	602	603	Brown clay & soapstone.	
	603	610	Red shale (firm)	
				Total Depth of Well - 604 ft.
				Set up face east
				Pit on south