

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Stanton	Fraction SE 1/4 SE 1/4 SW 1/4	Section number 26	Township number T 28 S	Range number R 39 E/W
----------------------	--------------------------	----------------------------------	----------------------	---------------------------	--------------------------

2. Distance and direction from nearest town or city: Street address of well location if in city:	10 1/2 miles west of Ulysses, Ks.	3. Owner of well: R.R. or street: City, state, zip code:	Melvin Wilson Ulysses, Kansas 67880
---	--	--	--

4. Locate with "X" in section below:	Sketch map:

6. Bore hole dia. <u>9 1/2</u> in. Completion date _____ Well depth <u>455</u> ft. <u>10/4/76</u>
7. <u>X</u> Cable tool <u>X</u> Rotary <u> </u> Driven <u> </u> Dug <u> </u> Hollow rod <u> </u> Jetted <u> </u> Bored <u> </u> Reverse rotary
8. Use: <u>X</u> Domestic <u> </u> Public supply <u> </u> Industry <u> </u> Irrigation <u> </u> Air conditioning <u> </u> Stock <u> </u> Lawn <u> </u> Oil field water <u> </u> Other
9. Casing: Material <u>STYRENE</u> Right <u> </u> Above or below Threaded <u> </u> Welded <u>g1</u> Surface <u>14</u> in. RMP <u> </u> PVC <u> </u> Weight _____ lbs./ft. Dia. <u>5</u> in. to <u>355</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <u>320</u>

5. Type and color of material	From	To
Surface	0	2
Fine sandy clay	2	189
Fine sand and brown clay strips	189	220
Blue and brown clay w/fine sand stirps	220	425
Fine to medium sand w/clay strips	425	455

10. Screen: Manufacturer's name Sunflower Type <u>styrene</u> Dia. <u>5"</u> Slot/gauze <u>1/16</u> Length <u>100</u> Set between <u>355</u> ft. and <u>455</u> ft. <u> </u> ft. and <u> </u> ft. Gravel pack? <u>X</u> Size range of material <u>No. 1</u>
11. Static water level: _____ mo./day/yr. <u>220</u> ft. below land surface Date <u>8/30/76</u>
12. Pumping level below land surfaces: <u>236</u> ft. after <u>24</u> hrs. pumping <u>10</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield _____ g.p.m.
13. Water sample submitted: _____ mo./day/yr. Yes <u>X</u> No _____ Date _____
14. Well head completion: <u>X</u> Pitless adapter <u>14</u> inches above grade
15. Well grouted? <u>X</u> With: <u> </u> Neat cement <u>X</u> <u> </u> Bentonite <u> </u> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.
16. Nearest source of possible contamination: <u>NA</u> ft. _____ Direction _____ Type _____ Well disinfected upon completion? <u>X</u> Yes <u> </u> No
17. Pump: _____ Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <u> </u> Submersible <u> </u> Turbine <u> </u> Jet <u> </u> Reciprocating <u> </u> Centrifugal <u> </u> Other

18. Elevation: Topography: <u> </u> Hill <u>X</u> Slope <u> </u> Upland <u> </u> Valley	19. Remarks: (Use a second sheet if needed)	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Houck Bros. Drlg. Co. 164 Business name _____ License No. _____ Address <u>Box 487, Ulysses, Ks.</u> Signed <u>M. Beard</u> Date <u>11/10/76</u> Authorized representative
---	--	--

T 28 39 R 26. SESESW 1/4 1/4 9/4