



Approx. 2 miles north of Johnson.

Board of Agriculture, Division of Water Resources

Application Number: 11.285 & 22.910

4) DEPTH OF COMPLETED WELL . . . . . 59.3 . . . . . ft. ELEVATION: . . . . .

Depth(s) Groundwater Encountered 1. . . . . ft. 2. . . . . ft. 3. . . . . ft.

WELL'S STATIC WATER LEVEL . . . . . 29.7 . . . . . ft. below land surface measured on mo/day/yr . . . . . 5/14/90

Pump test data: Well water was . . . . . 4.65 . . . . . ft. after . . . . . 4 . . . . . hours pumping . . . . . 1000 . . . . . gpm

Est. Yield . . . . . 800gpm: Well water was . . . . . ft. after . . . . . hours pumping . . . . . gpm

Bore Hole Diameter . . . . . 2.4 . . . . . in. to . . . . . 59.3 . . . . . ft., and . . . . . in. to . . . . . ft.

WELL WATER TO BE USED AS:

1 Domestic	3 Feedlot	6 Oil field water supply	9 Dewatering	12 Other (Specify below)
<u>2 Irrigation</u>	4 Industrial	7 Lawn and garden only	10 Monitoring well	

Was a chemical/bacteriological sample submitted to Department? Yes . . . . . No . . . . . X . . . . . If yes, mo/day/yr sample was submitted . . . . .

Water Well Disinfected? Yes . . . . . No . . . . . X . . . . .

1 <u>Steel</u>	3 RMP (SR)	6 Asbestos-Cement	9 Other (specify below)	Welded . . . . .X
2 PVC	4 ABS	7 Fiberglass		Threaded . . . . .
Blank casing diameter . . . . .16 . . . . .in. to . . . . .593 . . . . .ft., Dia . . . . .in. to . . . . .ft., Dia . . . . .in. to . . . . .ft.				
Casing height above land surface . . . . .12 . . . . .in., weight . . . . .42.05 . . . . .lbs./ft. Wall thickness or gauge No. . . . .250 . . . . .				
TYPE OF SCREEN OR PERFORATION MATERIAL:			7 PVC	10 Asbestos-cement
1 <u>Steel</u>	3 Stainless steel	5 Fiberglass	8 RMP (SR)	11 Other (specify) . . . . .
2 <u>Brass</u>	4 Galvanized steel	6 Concrete tile	9 ABS	12 None used (open hole)

6 GROUT MATERIAL:		1 Neat cement	2 Cement grout	3 Bentonite	4 Other
Grout Intervals:		From . . . . . 0 . . . . . ft. to . . . . . 2 . . . . . ft.,	From . . . . . ft. to . . . . . ft.,	From . . . . . ft. to . . . . . ft.,	From . . . . . ft. to . . . . . ft.
What is the nearest source of possible contamination:				10 Livestock pens	14 Abandoned water well
1 Septic tank	4 Lateral lines	7 Pit privy	11 Fuel storage	15 Oil well/Gas well	
2 Sewer lines	5 Cess pool	8 Sewage lagoon	12 Fertilizer storage	16 Other (specify below)	
3 Watertight sewer lines	6 Seepage pit	9 Feedyard	13 Insecticide storage		
Direction from well? South East			How many feet?	265'	

[illegible]

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) May 11, 1990 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 145 This Water Well Record was completed on (mo/day/yr) May 15, 1990 under the business name of Henkle Drilling & Supply Co., Inc. by (signature) Bruce R. Schmitt

# DRILLERS TEST LOG

CUSTOMER'S NAME: Circle 8 Farms DATE: March 21, 1990  
STREET ADDRESS: Box 506 TEST # 1 E. LOG Yes  
CITY & STATE: Johnson, Ks. 67855 DRILLER Shelden  
COUNTY Stanton QUARTER SW SECTION 18 TOWNSHIP 28 RANGE 40  
LOCATION 300' east of old well.

[illegible]

GARDEN CITY, KS 67846  
3795 West Jones Ave.

HENKLE DRILLING & SUPPLY CO., INC.

316-277-2389

## IRRIGATION HEADQUARTERS

TEST HOLES \* \* \* \* \* IRRIGATION & INDUSTRIAL WELLS \* \* \* \* \* STOCK WELLS