

DRILLERS TEST LOG

CUSTOMERS NAME Leroy Cockrum DATE 9-12-79
STREET ADDRESS _____ TEST # 1 E LOG yes
CITY & STATE Johnson, Ks. 67855 DRILLER Livingston
COUNTY Stanton QUARTER SW SECTION 8 TOWNSHIP 28 RANGE 41
LOCATION 100' NorthWest of old well

WELL LOCATION

	DRILLED FROM	PAY	FOOTAGE TO	DESCRIPTION OF STRATA	STATIC WATER LEVEL PROPOSED WELL DEPTH 554'
	0		2	Top Soil	
	2		16	Silt & Sandy Clay	
	16		38	Brown Clay & few fine sand st.	
	38		57	Sand fine to med. coarse, coarse	
	57		80	Clay & Sand fine to med. coarse	
	80		100	Sand fine to med. small gravel few clay st.	
	100		120	Brown Clay & Snad st.	
	120		135	Sand fine to med. coarse, small gravel	
	135		140	Brown clay	
	140		152	Sand fine & sandy clay	
	152		160	Sand fine to med. small gravel	
	160		176	Brown clay	
	176		250	Sand fine to med. small to med. brown gravel few clay st.	
	250		260	Brown sandy clay & fine sand	
70	260	27	287	Sand fine to med. coarse small to med. brown gravel & white & tan rock few clay st.	
	287		293	Brown sandy clay	
30	293	17	310	Gyp sand stone & brown rock & fine sand brown sandy clay drills loose used water.	
50	310	05	315	Brown rock & sandstone Used water.	
	315		329	Brown clay few fine sand st. (stickey)	
	329		390	weathered shale & few hard ledges	
fail	390	26	416	Shale & dakota st. & soapstone	
	416		420	False RED bed & soapstone	
	420		421	Very Hard	
fail	421	16	437	Dakota Limestone Very Hard 430	
good	437	114	551	Dakota & few soapstone st.	
	551		557	Soapstone & red bed	
				TOTAL DEPTH 554'	
				Set up SOUTH	
				Pits on WEST	

HENKLE DRILLING & SUPPLY CO., INC.

GARDEN CITY, KANSAS
Phone 276-3278

SUBLETTE, KANSAS
Phone 675-4311

TEST HOLES	DOMESTIC WELLS	STOCK WELLS	IRRIGATION & INDUSTRIAL WELLS
------------	----------------	-------------	-------------------------------