

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

Billed to: **Craig Roberts**

1. Location of well:	County Kingman	Fraction SW 1/4 SW 1/4 SE 1/4	Section number 5	Township number T 28 S R	Range number 5W E/W
2. Distance and direction from nearest town or city: 5 1/2 West of Cheney, Kansas Street address of well location if in city: on McArthur, on the			3. Owner of well: George Viney R.R. or street: RR#1 City, state, zip code: Murdock, Kansas		
4. Locate with "X" in section below: Sketch map: North side of the Road. Murdock, Kansas			6. Bore hole dia. 11 in. Completion date _____ Well depth 40 ft. 4-13-77		
			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material			9. Casing: Material Styrene Height: Above or below _____ Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC _____ Weight _____ lbs./ft. Dia. 5 in. to 40 ft. depth Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth Gauge No. .200		
Topsoil			10. Screen: Manufacturer's name Sunflower Plastic Type Styrene Dia. 5" Slot/gauze 1/16 Length 24' Set between 16 ft. and 40 ft. _____ ft. and _____ ft. Gravel pack? yes Size range of material 1/4-1/8"		
Clay			11. Static water level: _____ mo./day/yr. 15 ft. below land surface Date 4-13-77		
Fine Sand			12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
Shale			13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input type="checkbox"/> No Date _____		
			14. Well head completion: Capped <input type="checkbox"/> Pitless adapter 12 inches above grade		
			15. Well grouted? yes With: <input type="checkbox"/> Negt cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 40" ft. to 14 ft. O.K.		
			16. Nearest source of possible contamination: Septic ft. 100 Direction East Type Tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)					
18. Elevation:		19. Remarks: Customer specified the depth of the Well.		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name License No. Address Wichita, Kansas Signed M. Arnold Date 4-30-77 Authorized representative	
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley					

T
R
E
S
S
W
S
E
1/4
1/4
1/4