

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County KINGMAN Fraction 1/4 NW 1/4 SE 1/4 Section number 11 Township number T 28 S R 5 E/W Range number 5	
2. Distance and direction from nearest town or city: 2 1/2 WEST OF CHENEY, KANSAS	
3. Owner of well: GILBERT BROWN R.R. #1 CHENEY, KANSAS	
4. Locate with "X" in section below: Sketch map:	
5. Type and color of material	
SANDY SOIL	From 0 To 3
CLAY	From 3 To 23
FINE SAND	From 23 To 37
RED SHALE	From 37 To 75
6. Bore hole dia. 11 in. Completion date 9-9-76 Well depth 75 ft.	
7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
9. Casing: Material STYRENE Height Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 75 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gauge No. 1200	
10. Screen: Manufacturer's name SUNFLOWER PLASTIC Type STYRENE Dia. 5" Slot/gauze 106 Length 30' Set between 45 ft. and 75 ft. Gravel pack? YES Size range of material 1/4-1/8"	
11. Static water level: _____ mo./day/yr. 20 ft. below land surface Date 9-9-76	
12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.	
13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input type="checkbox"/> No Date _____	
14. Well head completion: 12 CAPPED <input type="checkbox"/> Pitless adapter _____ Inches above grade	
15. Well grouted? YES With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 40' to 14 ft.	
16. Nearest source of possible contamination: SEPTIC TANK ft. 60 Direction SW Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)	
18. Elevation: Topography: <input checked="" type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: 20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. HARP WELL PUMP 236 Business name _____ License No. _____ Address WICHITA, KANSAS Signed M. Arnold Date 10-5-76 Authorized representative

T 28
 R 5
 W 11
 E 11
 Sec 5
 1/4 1/4 1/4 1/4
 NWSE