

1 LOCATION OF WATER WELL
 County: KINGMAN Fraction C OFF NW 1/4 SW 1/4 Section Number 13 Township Number T 28 S Range Number R 8 E (W)

Distance and direction from nearest town or city? 2W 3 1/2 S OF KINGMAN, KS Street address of well if located within city?


2 WATER WELL OWNER: H-30 Drilling Company
 RR#, St. Address, Box #: 251 N. Water Suite 10 Board of Agriculture, Division of Water Resources
 City, State, ZIP Code: Wichita, Kansas 67202 Application Number:

3 DEPTH OF COMPLETED WELL: 60 ft. Bore Hole Diameter: 10 in. to ft., and in. to ft.
 Well Water to be used as:
 1 Domestic 3 Feedlot (6) Oil field water supply 8 Air conditioning 11 Injection well
 2 Irrigation 4 Industrial 7 Lawn and garden only 9 Dewatering 12 Other (Specify below)
 10 Observation well
 Well's static water level: 23 ft. below land surface measured on Apr month 1 day 81 year
 Pump Test Data: Well water was ft. after hours pumping. gpm
 Est. Yield 60 gpm: Well water was ft. after hours pumping. gpm

4 TYPE OF BLANK CASING USED:
 1 Steel (3) RMP (SR) 5 Wrought iron 8 Concrete tile Casing Joints: Glued X Clamped
 2 PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below) Welded
 7 Fiberglass Threaded
 Blank casing dia: 5 in. to 40 ft., Dia in. to ft., Dia in. to ft.
 Casing height above land surface: 12 in., weight lbs./ft. Wall thickness or gauge No. .214
 TYPE OF SCREEN OR PERFORATION MATERIAL:
 1 Steel 3 Stainless steel 5 Fiberglass (8) RMP (SR) 10 Asbestos-cement
 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 11 Other (specify)
 12 None used (open hole)
 Screen or Perforation Openings Are:
 1 Continuous slot 3 Mill slot 5 Gauzed wrapped (8) Saw cut 11 None (open hole)
 2 Louvered shutter 4 Key punched 6 Wire wrapped 9 Drilled holes
 7 Torch cut 10 Other (specify)
 Screen-Perforation Dia: 5 in. to ft., Dia in. to ft., Dia in. to ft.
 Screen-Perforated Intervals: From 40 ft. to 60 ft., From ft. to ft.
 Gravel Pack Intervals: From ft. to ft., From ft. to ft.
 From 10 ft. to 60 ft., From ft. to ft.

5 GROUT MATERIAL: (6) Neat cement 2 Cement grout 3 Bentonite 4 Other
 Grouted Intervals: From 0 ft. to 10 ft., From ft. to ft., From ft. to ft.
 What is the nearest source of possible contamination:
 1 Septic tank 4 Cess pool 7 Sewage lagoon 10 Fuel storage 14 Abandoned water well
 2 Sewer lines 5 Seepage pit 8 Feed yard 11 Fertilizer storage 15 Oil well/Gas well
 3 Lateral lines 6 Pit privy 9 Livestock pens 12 Insecticide storage 16 Other (specify below) None
 13 Watertight sewer lines
 Direction from well How many feet ? Water Well Disinfected? Yes X No
 Was a chemical/bacteriological sample submitted to Department? Yes No X If yes, date sample
 was submitted month day year: Pump Installed? Yes No X
 If Yes: Pump Manufacturer's name Model No. HP Volts
 Depth of Pump Intake ft. Pumps Capacity rated at gal./min.
 Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other

6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was
 completed on APRIL month 1 day 81 year 325
 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No.
 This Water Well Record was completed on JUNE month 9 day 81 year under the business
 name of Central Well & Pump Inc. Pratt, Kansas by (signature) LB Stonomehl

7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:


FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG
0	2	Top soil			
2	5	Clay, brown			
5	30	Sand, fine to med			
30	50	Sand, fine to coarse with a little fine gravel, loose			
50	58	Sand, fine to med			
58	80	Clay, blue			
80	85	Sand, very fine to fine, silty			
85	90	Shale, red			

ELEVATION:

Depth(s) Groundwater Encountered 1. 23 ft. 2. ft. 3. ft. 4. ft. (Use a second sheet if needed)