

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County KINGMAN	Fraction NW 1/4 SE 1/4 SE 1/4	Section number 1	Township number T 28 S	Range number R 9 E
2. Distance and direction from nearest town or city: 7W 1/2S KINGMAN Street address of well location if in city:			3. Owner of well: MATH BIEFER R.R. or street: RFO 1 City, state, zip code: KINGMAN, KS 67068		
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: N SEPTIC TANK WELL 425' 300' ROAD S		
5. Type and color of material			From	To	6. Bore hole dia. 10 in. Completion date 4/21/79 Well depth 30 ft.
TOP SOIL			0	1	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
MED SAND & CLAY			1	10	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
CLAY			10	18	9. Casing: Material PLT Height: Above or below Threaded <input type="checkbox"/> Welded GLUE Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 2.827 lbs./ft. Dia. 5 in. to 20 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 258
MED SAND			18	20	10. Screen: Manufacturer's name PUMPCO Type PVC Dia. 5" Slot/gauze .030 Length 10' Set between 20 ft. and 30 ft. ft. and <input type="checkbox"/> ft.
CLAY			20	24	11. Static water level: <input type="checkbox"/> mo./day/yr. 10 ft. below land surface Date 4/10/79
MED-COURSE SAND			24	30	12. Pumping level below land surfaces: 20 ft. after 1 hrs. pumping 40 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 30 g.p.m.
RED BED			30		13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>
					14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> _____ inches above grade
					15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 4 ft. to 14 ft.
					16. Nearest source of possible contamination: ft. 425' Direction E Type SEPTIC Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: <input type="checkbox"/> Not installed Manufacturer's name SIA-RITE Model number 20P4EC2 HP 1 Volts 230 Length of drop pipe _____ ft. capacity 30 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. SMITH CENTRAL IRR. 355 Business name License No. Address Box 226 - KINGMAN, KS. Signed Alean K. Wallace Date 5/12/79 Authorized representative		
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

28
9
1
1/4 1/4 1/4
N 9 E SE