


1 LOCATION OF WATER WELL		Fraction	Center of		Section Number	Township Number		Range Number	
County: Kingman		$\frac{1}{4}$	NE $\frac{1}{4}$ NE $\frac{1}{4}$		33	T 28 S		R 9 EW	
Distance and direction from nearest town or city? 9 N & 1 W OF ZENDA, KS					Street address of well if located within city?				
2 WATER WELL OWNER:		Brandt Drilling Company							
RR#, St. Address, Box # :		Suite 1104 Douglas Bldg.							
City, State, ZIP Code :		Wichita, Kansas 67202							
		Board of Agriculture, Division of Water Resources							
		Application Number:							
3 DEPTH OF COMPLETED WELL:		125 ft. Bore Hole Diameter: 10 in. to 125 ft., and in. to ft.							
Well Water to be used as:		5 Public water supply 8 Air conditioning 11 Injection well							
1 Domestic 3 Feedlot		6 Oil field water supply 9 Dewatering 12 Other (Specify below)							
2 Irrigation 4 Industrial		7 Lawn and garden only 10 Observation well							
Well's static water level: 54 ft. below land surface measured on		JUNE month 7 day 80 year							
Pump Test Data :		Well water was ft. after hours pumping. gpm							
Est. Yield 100 gpm:		Well water was ft. after hours pumping. gpm							
4 TYPE OF BLANK CASING USED:		5 Wrought iron 8 Concrete tile Casing Joints: Glued X Clamped							
1 Steel		3 RMP (SR) 6 Asbestos-Cement 9 Other (specify below) Welded							
2 PVC		4 ABS 7 Fiberglass Threaded							
Blank casing dia 5 in. to 105 ft., Dia		in. to ft., Dia in. to ft.							
Casing height above land surface: 12 in., weight		lbs./ft. Wall thickness or gauge No 200							
TYPE OF SCREEN OR PERFORATION MATERIAL:		7 PVC 10 Asbestos-cement							
1 Steel 3 Stainless steel 5 Fiberglass		8 RMP (SR) 11 Other (specify)							
2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS		12 None used (open hole)							
Screen or Perforation Openings Are:		5 Gauzed wrapped 8 Saw cut 11 None (open hole)							
1 Continuous slot 3 Mill slot 6 Wire wrapped 9 Drilled holes		2 Louvered shutter 4 Key punched 7 Torch cut 10 Other (specify)							
Screen-Perforation Dia 5 in. to ft., Dia		in. to ft., Dia in. to ft.							
Screen-Perforated Intervals:		From 105 ft. to 125 ft., From ft. to ft.							
Gravel Pack Intervals:		From 10 ft. to 125 ft., From ft. to ft.							
5 GROUT MATERIAL:		1 Neat cement 2 Cement grout 3 Bentonite 4 Other							
Grouted Intervals: From 0 ft. to 10 ft., From		ft. to ft., From ft. to ft.							
What is the nearest source of possible contamination:		10 Fuel storage 14 Abandoned water well							
1 Septic tank 4 Cess pool 7 Sewage lagoon 11 Fertilizer storage 15 Oil well/Gas well		2 Sewer lines 5 Seepage pit 8 Feed yard 12 Insecticide storage 16 Other (specify below)							
3 Lateral lines 6 Pit privy 9 Livestock pens 13 Watertight sewer lines		X NONE							
Direction from well: How many feet ?		Water Well Disinfected? Yes X No							
Was a chemical/bacteriological sample submitted to Department? Yes No X		If yes, date sample							
was submitted month day year: Pump Installed? Yes No X		Model No. HP Volts							
If Yes: Pump Manufacturer's name		Depth of Pump Intake ft. Pumps Capacity rated at gal./min.							
Type of pump:		1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other							
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was		constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was							
completed on		JUNE month 7 day 80 year							
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 325		This Water Well Record was completed on							
name of Central Well & Pump Inc. Pratt, Kansas		by (signature) J. Hanomichl							
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		FROM TO LITHOLOGIC LOG FROM TO LITHOLOGIC LOG							
		0 2		Top soil				fine to med gravel	
		2 19		Clay, brown					
		19 29		Sand, fine to coarse					
		29 40		Clay, tan					
		40 90		Sand, fine to coarse and medium gravel					
		90 103		Clay, tan					
		103 125		Sand, fine to coarse and fine to med gravel					
125 138		Clay, tan							
ELEVATION:		138 160		Sand, fine to coarse and					
Depth(s) Groundwater Encountered		1. 54 ft. 2. ft. 3. ft. 4. ft. (Use a second sheet if needed)							

OFFICE USE ONLY

T

28

R

9

END

SEC.

33

Center of NE 1/4 NE 1/4

NE 1/4

NE 1/4