

Copy - PS (Block)

1 LOCATION OF WATER WELL
 County: Sedgwick Fraction: SE 1/4 SE 1/4 SE 1/4 Section Number: 2 Township Number: T 29 S Range Number: R 1 E/W

Distance and direction from nearest town or city? 1 mile South of 1 mile West of Haysville Street address of well if located within city? 79th South of 39th West

2 WATER WELL OWNER: City of Haysville Well No. 6 (TH 1-81)
 RR#, St. Address, Box #: Haysville, Kansas 67060 Board of Agriculture, Division of Water Resources
 City, State, ZIP Code: Haysville, Kansas 67060 Application Number: 31895

3 DEPTH OF COMPLETED WELL: 81 ft. Bore Hole Diameter: 38 in. to ... ft. and ... in. to ... ft.
 Well Water to be used as:
 1 Domestic 3 Feedlot 5 Public water supply 8 Air conditioning 11 Injection well
 2 Irrigation 4 Industrial 6 Oil field water supply 9 Dewatering 12 Other (Specify below)
 7 Lawn and garden only 10 Observation well

Well's static water level: 34 ft. below land surface measured on ... month 15 day 82 year
 Pump Test Data: Well water was 57 ft. after 5 hours pumping 500 gpm
 Est. Yield gpm: Well water was ... ft. after ... hours pumping

4 TYPE OF BLANK CASING USED:
 1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile Casing Joints: Glued ... Clamped ...
 2 PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below) Welded X
 7 Fiberglass Threaded ...

Blank casing dia: 12 in. to ... ft. Dia: 7 1/3 in. to ... ft. Dia: ... in. to ... ft.
 Casing height above land surface: ... in., weight: 43.77 lbs./ft. Wall thickness or gauge No: 330

TYPE OF SCREEN OR PERFORATION MATERIAL:
 1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 10 Asbestos-cement 11 Other (specify) ...
 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 12 None used (open hole)

Screen or Perforation Openings Are:
 1 Continuous slot 3 Mill slot 5 Gauzed wrapped 8 Saw cut 11 None (open hole)
 2 Louvered shutter 4 Key punched 6 Wire wrapped 9 Drilled holes
 7 Torch cut 10 Other (specify)

Screen-Perforation Dia: 12 in. to ... ft. Dia: 81 in. to ... ft. Dia: ... in. to ... ft.
 Screen-Perforated Intervals: From 71 ft. to 81 ft. From ... ft. to ... ft. From ... ft. to ... ft.
 Gravel Pack Intervals: From 22 ft. to 81 ft. From ... ft. to ... ft. From ... ft. to ... ft.

5 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Clay Other ...
 Grouted Intervals: From 20 ft. to 22 ft. From 20 ft. to 0 ft. From ... ft. to ... ft.

What is the nearest source of possible contamination:
 1 Septic tank 4 Cess pool 7 Sewage lagoon 10 Fuel storage 14 Abandoned water well
 2 Sewer lines 5 Seepage pit 8 Feed yard 11 Fertilizer storage 15 Oil well/Gas well
 3 Lateral lines 6 Pit privy 9 Livestock pens 12 Insecticide storage 16 Other (specify below)
 13 Watertight sewer lines

Direction from well: North How many feet: 8000 ? Water Well Disinfected? Yes X No

Was a chemical/bacteriological sample submitted to Department? Yes No X If yes, date sample was submitted ... month ... day ... year: Pump Installed? Yes X No

If Yes: Pump Manufacturer's name: Layne Model No: 90EH HP: 20 Volts: 460
 Depth of Pump Intake: 73 ft. Pumps Capacity rated at: 500 gal. min.
 Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other

6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on April month 15 day 1982 year
 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 102
 This Water Well Record was completed on April month 21 day 1982 year under the business name of Layne Western Co., Inc. by (signature) R.D. Hook

7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:

FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG
0	3	Top soil			
3	5	Gray clay			
5	10	Gray & tan clay			
10	20	Med. sand			
20	25	Med-co. sand/tan clay			
25	30	Fine-med. sand			
30	35	Med. sand			
35	60	Co. sand/med. gravel			
60	70	Med-co. sand			
70	85	Med.-co. sand/med. gr.			
ELEVATION:	85	86			

Depth(s) Groundwater Encountered 1. 34 ft. 2. ... ft. 3. ... ft. 4. ... ft. (Use a second sheet if needed)

INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.

OFFICE USE ONLY

T

R

SEC

SE 1/4 SE 1/4 SE 1/4 SE 1/4