USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
	Sedgwick	NE 1/4 SE 1/4 NE 1/4	25	T 29 S	R 1 E (W)

2. Distance and direction from nearest town or city:
Street address of well location if in city: 1 3/4 m N. Peck

3. Owner of well: Charles Ott
R.R. or street:
City, state, zip code: Peck, Kansas

4. Locate with "X" in section below: Sketch map:

N
NW NE X
W E
SW SE
S
1 Mile 1 Mile

open field

6. Bore hole dia. 30 in. Completion date 7/8/77
Well depth 72' ft.

7. __ Cable tool __ Rotary __ Driven __ Dug
__ Hollow rod __ Jetted __ Bored X Reverse rotary

8. Use: __ Domestic __ Public supply __ Industry
X Irrigation __ Air conditioning __ Stock
__ Lawn __ Oil field water __ Other

9. Casing: Material C-Asb Height: Above or below
Threaded ___ Welded ___ Surface 18 in.
RMP ___ PVC ___ Weight ___ lbs./ft.
Dia. 16 in. to 46 ft. depth Wall Thickness: inches or
Dia. ___ in. to ___ ft. depth gage No. 3/4

5. Type and color of material	From	To
Topsoil	0	1
Clay	1	3
Fine Sand	3	15
Med Sand	15	41
Clay	41	45
Good Gravel	45	76

(Use a second sheet if needed)

10. Screen: Manufacturer's name Johnson
Type Cem-Asb Dia. 16"
Slot/gauze 1/4" Length 26'
Set between 46 ft. and 76 ft.
___ ft. and ___ ft.
Gravel pack? X Size range of material 3/8

11. Static water level: mo./day/yr.
32 ft. below land surface Date 6/30/77

12. Pumping level below land surfaces:
40 ft. after 2 hrs. pumping 600 g.p.m.
___ ft. after ___ hrs. pumping ___ g.p.m.
Estimated maximum yield 800 g.p.m.

13. Water sample submitted: mo./day/yr.
___ Yes X No Date

14. Well head completion:
___ Pitless adapter 18 Inches above grade

15. Well grouted? X
With: ___ Neat cement ___ Bentonite X Concrete
Depth: From 0 ft. to 10 ft.

16. Nearest source of possible contamination: none
ft. ___ Direction ___ Type
Well disinfected upon completion? ___ Yes X No

17. Pump: ___ Not installed
Manufacturer's name Peerless
Model number 7518 HP 15 Volts
Length of drop pipe 60 ft. capacity 500 g.p.m.
Type:
___ Submersible X Turbine
___ Jet ___ Reciprocating
___ Centrifugal ___ Other

18. Elevation:
Topography:
___ Hill
___ Slope
X Upland
___ Valley

19. Remarks:

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Weninger Irrigation 238
Business name License No.
Address Maize, Ks.
Signed R. Weninger Date 8/5/77
Authorized representative

T 29 R 1 (W) Sec 25 1/4 NE 1/4 SE 1/4 NE 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

MI-1023