## WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

| County , Fraction  | Section        | number  | Township number Range number  |
|--|----------------|---|---|
| 1. Location of well: Pratt July 5E 1/4 SE 1/4  | 4 /            |   | 1 29 S R // W E/W   |
| 2. Distance and direction from nearest town or city: 5 N of 3. Owner of well: Kenneth Blackwelder  |                |   |   |
| Street address of well location if in city:  R.R. or street:  City, state, zip code:  City, state, zip |                |   |   |
| 4. Locate with "X" in section below:  Sketch map:  |                |   | 6. Bore hole dia. 10 in. Completion date  |
| N  |                |   | Well depth 130 ft. 24 ms 4 78   |
| Set.   |                | 7 Cable tool X Rotary Driven Dug Hollow rod Jetted Bored Reverse rotary |   |
| X House -  |                | 8. Use: X Domestic Public supply Industry                               |   |
| * W  |                | Irrigation Air conditioning Stock<br>Lawn Oil field water Other         |   |
| sw  si   |                | 9. Casing: Material Height: Nove or below                               |   |
| Y V V  |                | Threaded Surface in .  RMP PVC Weight lbs./ft.                          |   |
| 1 Mile drunage.  |                | Dia. 5 in. to 10 ft. depth Wall Thickness: inches or                    |   |
| 5. Type and color of material  | From           | То  | Diain. toft. depth gage No  |
| Soil   | 0              | 4   | 10. Screen: Manufacturer's name  Services  Type Services  Dia. 5  |
|  | 4              | 9   | Slot/gauze Length 20/   |
| Clay, gray blue  | <del>-  </del> |   | Set betweenft. andft.   |
| Clay, white and tan  | 9              | 30  | Gravel pack? X Size range of material   |
| Clay, blue tan and stickey   | 30             | 48  | 11. Static water level: mo./day/yr.   |
| Clay, Brown and sandy  | 48             | 56  | 12. Pumping level below land surfaces:  |
| Sand, fine and med. gravel   | 56             | 64  | ft. after hrs. pumping g.p.m ft. after hrs. pumping g.p.m.  |
| Sand, fine with streaks of clay  | 64             | 75  | Estimated maximum yieldg.p.m.   |
|  |                |   | 13. Water sample submitted: mo./day/yr.   |
| Clay, tan  | 75             | 82  | 14. Well head completion:  X Pitless adapter  |
| Sand, very fine to fine and gravel   | 82             | 103   | X Pitless adapter 12 Inches above grade   |
| Sand, fine, tight with gravel and caliche  | 103            | 110   | With: Neat cament Bentonite Concrete  |
| Sand, fine and fine to med, gravel   | 110            | 135   | 1   |
| band, line and line to med, graver   | 110            | 177   | 16. Negrest source of possible contemination:  ft   |
|  |                |   | 17. Pump: Not installed   |
|  |                |   | Manufacturer's name STA KITE  Model number 52 20 HP / Volts 250   |
|  |                |   | Length of drop pipe $100$ ft. capacity $25$ g.p.m.  |
|  |                |   | Type:  X Submersible Turbine  |
| (Use a second sheet if needed)   |                |   | Jet Reciprocating Centrifugal Other   |
| 18. Elevation: 19. Remarks:  |                |   | 20. Water well contractor's certification:  |
| 4/X4/X4" Slal pour   |                |   | This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. |
| Topography:  |                |   | Central Well & Pump Svc. 325  |
| Hill Slope Lelow pitters adapter   |                |   | Business name Address 21 S Taylor Pratt Ks  |
| Upland Valley  |                |   | Signed Authorized representative AUL 79   |
| Forward the white, blue and pink copies to the Department of Health and Environment  |                | 1   | Form WWC-5  |